

## **PART 1 GENERAL**

### **1.1 REFERENCE STANDARDS**

- .1 ASTM International
  - .1 ASTM A 167-99(2009), Standard Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip.
  - .2 ASTM B 456-17, Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium.
  - .3 ASTM A 653/A 653M-15e1, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- .2 CSA International
  - .1 CAN/CSA-B651-12, Accessible Design for the Built Environment.

### **1.2 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature and data sheets and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
  - .1 Indicate size and description of components, base material, surface finish inside and out, hardware and locks, attachment devices, description of rough-in-frame, building-in details of anchors for grab bars.

### **1.3 CLOSEOUT SUBMITTALS**

- .1 Provide maintenance data for toilet and bath accessories for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

### **1.4 MAINTENANCE MATERIAL SUBMITTALS**

- .1 Tools:
  - .1 Provide special tools required for assembly, disassembly or removal for toilet and bath accessories in accordance with requirements specified in Section 01 78 00 - Closeout Submittals.
  - .2 Deliver special tools to Departmental Representative.

---

## **1.5 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
  - .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect toilet and bathroom accessories from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.

## **PART 2 PRODUCTS**

### **2.1 MATERIALS**

- .1 Sheet steel: to ASTM A653/A653M with ZF001 designation zinc coating.
- .2 Stainless steel sheet metal: to ASTM A 167, Type 304, with #4 finish.
- .3 Stainless steel tubing: Type 304, commercial grade, seamless welded, 1.2 mm wall thickness.
- .4 Fasteners: concealed screws and bolts hot dip galvanized, exposed fasteners to match face of unit. Expansion shields fibre, lead or rubber as recommended by accessory manufacturer for component and its intended use.

### **2.2 COMPONENTS**

- .1 Toilet tissue dispenser: double roll type, surface mounted, chrome plated steel frame, capacity of 500 double ply roll, roll under spring tension for controlled delivery.
- .2 Paper towel dispenser: for double fold paper towels, stainless steel cabinet, hinged front panel, refill indicator slot, lock and key, surface mounted.
- .3 Combination towel dispenser/waste receptacle: surface mounted wall unit, approximately 430 mm wide, 1422 mm high, 190 mm deep. Interior of 0.8 mm galvanized steel, exterior of 0.8 mm stainless steel. Suitable for dispensing folded or roll paper towels. Removable galvanized steel waste receptacle, lockable access door with continuous full height stainless steel hinge.
- .4 Soap dispenser: liquid push-in valve, self contained 1.14 L tank , push-in corrosion resistant valve assembly, tamper proof filler lock, surface mounted, exposed metal components stainless steel.
- .5 Shower curtain: anti-bacterial fire resistive self extinguishing vinyl laminated fabric shower curtain. Provide curtain hold-back hook and chain at each curtain.

- .6 Shower rods: 25 mm diameter x 1.2 mm wall thickness stainless steel tubing of required length with satin chrome finished flanges, 12 shower curtain hooks and curtain hold-back hook and chain. Shower rod material and anchorage to withstand downward pull of 0.9 kN.
- .7 Grab bars: 38 mm diameter x 1.6 mm wall] tubing of stainless steel, 76 mm diameter wall flanges, concealed screw attachment, flanges welded to tubular bar, provided with steel back plates and all accessories. Knurl bar at area of hand grips. Grab bar material and anchorage to withstand downward pull of 2.2 kN.
- .8 Soap holder: surface mounted, 5 mm thick stainless steel dished tray, self draining, flush screws.
- .9 Deodorant block holders: 200 x 75 mm perforated design, stainless steel.
- .10 Robe hook: stainless steel with 75 mm projection.
- .11 Mirror: wall mounted unit, fixed framed mirror 6 mm, stainless steel frame. Size 450x913 mm (W x H)

## 2.3 FABRICATION

- .1 Weld and grind joints of fabricated components flush and smooth. Use mechanical fasteners only where approved.
- .2 Wherever possible form exposed surfaces from one sheet of stock, free of joints.
- .3 Brake form sheet metal work with 1.5 mm radius bends.
- .4 Form surfaces flat without distortion. Maintain flat surfaces without scratches or dents.
- .5 Back paint components where contact is made with building finishes to prevent electrolysis.
- .6 Hot dip galvanize concealed ferrous metal anchors and fastening devices to CAN/CSA-G164.
- .7 Shop assemble components and package complete with anchors and fittings.
- .8 Deliver inserts and rough-in frames to job site at appropriate time for building-in. Provide templates, details and instructions for building in anchors and inserts.
- .9 Provide steel anchor plates and components for installation on studding and building framing.

## 2.4 FINISHES

- .1 Manufacturer's or brand names on face of units not acceptable.

## **PART 3 EXECUTION**

### **3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrates and surfaces to receive toilet and bathroom accessories previously installed under other Sections or Contracts are acceptable for product installation in accordance with manufacturer's instructions prior to toilet and bathroom accessories installation.
- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied.

### **3.2 INSTALLATION**

- .1 Install and secure accessories rigidly in place as follows:
  - .1 Stud walls: install steel back-plate to stud prior to plaster or drywall finish. Provide plate with threaded studs or plugs.
  - .2 Hollow masonry units, existing plaster or drywall: use toggle bolts drilled into cell or wall cavity.
  - .3 Solid masonry, marble, stone or concrete: use bolt with lead expansion sleeve set into drilled hole.
  - .4 Toilet and shower compartments: use male to female through bolts.
- .2 Install grab bars on built-in anchors provided by [bar manufacturer].
- .3 Use tamper proof screws/bolts for fasteners.
- .4 Fill units with necessary supplies shortly before final acceptance of building.

### **3.3 ADJUSTING**

- .1 Adjust toilet and bathroom accessories components and systems for correct function and operation in accordance with manufacturer's written instructions.
- .2 Lubricate moving parts to operate smoothly and fit accurately.

### **3.4 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
- .2 Leave Work area clean at end of each day.
- .3 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

### **3.5 PROTECTION**

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by toilet and bathroom accessories installation.

**END OF SECTION**