
PART 1 GENERAL

1.1 REFERENCE STANDARDS

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA-B45 Series (Latest Edition), Plumbing Fixtures, (Consists of B45.0, B45.1, B45.2, B45.3, B45.4, B45.5, B45.6, B45.7, B45.8 and B45.9).
 - .2 CAN/CSA-B125.3 (Latest Edition), Plumbing Fittings.
 - .3 CAN/CSA-B651 (Latest Edition), Accessible Design for the Built Environment.
- .2 National Research Council Canada (NRC)
 - .1 National Building Code of Canada 2015 (NBC).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for fixtures, and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data including monitoring requirements for incorporation into manuals specified in Section 01 78 00 - Closeout Submittals.
- .2 Include:
 - .1 Description of fixtures and trim, giving manufacturer's name, type, model, year, capacity.
 - .2 Details of operation, servicing, maintenance.
 - .3 List of recommended spare parts.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

PART 2 PRODUCTS

2.1 MANUFACTURED UNITS

- .1 Fixtures: manufacture in accordance with CAN/CSA-B45 series.

- .2 Trim, fittings: manufacture in accordance with CAN/CSA-B125.3.
- .3 Exposed plumbing brass to be chrome plated.
- .4 Number, locations: architectural drawings to govern.
- .5 Fixtures in any one location to be product of one manufacturer and of same type.
- .6 Trim in any one location to be product of one manufacturer and of same type.
- .7 Individual shower stall showerhead.
 - .1 SH-1: individual showerhead.
 - .1 Chrome plated brass, non-clog, with adjustable spray, ball joint, standard chrome plated bent arm and escutcheon. Limit maximum flow rate to 9.5 l/minute at 550 kPa.
 - .2 Shower supply valve:
 - .1 Pressure-balanced-actuated element, volume control, 40 degrees C maximum setting, strainer and check-stops on each inlet, lever handle.
- .8 PSC-1: metal shower cabinet (for SH-1)
 - .1 Cabinet: bonderized white baked enamel finish on galvanized steel.
 - .2 Sizes: 825 W x 900 D x 2100 L mm high.
 - .3 Base: Chrome plated brass strainer and tailpiece.
 - .4 Accessories: Soap dish, plastic curtain and hooks.
- .9 Fixture piping:
 - .1 Hot and cold-water supplies to each fixture.
 - .1 Chrome plated flexible supply pipes each with handwheel stop, reducers, escutcheon.
 - .2 Waste:
 - .1 Brass P trap with cleanout on each fixture not having integral trap.
 - .2 Chrome plated in all exposed places.

PART 3 EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Mounting heights:
 - .1 Standard: to comply with manufacturer's recommendations unless otherwise indicated or specified.

- .2 Physically handicapped: to comply with most stringent of either NBC or CAN/CSA B651.

3.3 ADJUSTING

- .1 Conform to water conservation requirements specified this section.
- .2 Adjustments:
 - .1 Adjust water flow rate to design flow rates.
 - .2 Adjust pressure to fixtures to ensure no splashing at maximum pressures.
- .3 Checks:
 - .1 Aerators: operation, cleanliness.
 - .2 Vacuum breakers, backflow preventers: operation under all conditions.
- .4 Thermostatic controls:
 - .1 Verify temperature settings, operation of control, limit and safety controls.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION