
Part 1 GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for fused and non-fused disconnect switches.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
 - .1 CAN/CSA C22.2 No.4-2016, Enclosed Switches.
 - .2 CSA C22.2 No.39-2013, Fuseholder Assemblies.

1.3 SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

Part 2 PRODUCTS

2.1 DISCONNECT SWITCHES

- .1 Fusible and non-fusible, disconnect switch in CSA Enclosure 1, size as indicated.
- .2 Provision for padlocking in on-off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuses: size as indicated, in accordance with Section 26 28 13.01 - Fuses - Low Voltage.
- .5 Fuseholders: suitable without adaptors, for type and size of fuse indicated.
- .6 Quick-make, quick-break action.
- .7 ON-OFF switch position indication on switch enclosure cover.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

Part 3 EXECUTION

3.1 INSTALLATION

- .1 Install disconnect switches complete with fuses if applicable.

END OF SECTION