
PART 1 GENERAL

1.1 REFERENCES

- .1 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-19.13M-M87, Sealing Compound, One Component, Elastomeric Chemical Curing.
 - .2 CAN/CGSB-19.24M-M90, Multi-Component, Chemical Curing Sealing Compound.
 - .3 CGSB 19-GP-14M-84, Sealing Compound, One Component, Butyl-Polyisobutylene Polymer Base, Solvent Curing.
- .2 Sealant and Waterproofer's Institute - Sealant and Caulking Guide Specification.

1.2 SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 01 33 00 – Submitted Procedures.

1.3 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Applicator: company specializing in performing work of this section [with minimum 5 years experience with installation of air/vapour barrier systems.
 - .1 Completed installation must be approved by the material manufacturer.
- .2 Mock-Up:
 - .1 Construct mock-up in accordance with Section 01 45 00 - Quality Control.
 - .2 Construct typical exterior wall panel, 10m² minimum, incorporating window and frame and sill, insulation, building corner condition, junction with roof system and; illustrating materials interface and seals.
 - .3 Locate where directed.
 - .4 Mock-up may remain as part of finished work.
 - .5 Allow 2 working days hours for inspection of mock-up by Departmental Representative before proceeding with air/vapour barrier Work.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

- .3 Avoid spillage: immediately notify Departmental Representative if spillage occurs and start clean up procedures.
- .4 Clean spills and leave area as it was prior to spill.

1.5 AMBIENT CONDITIONS

- .1 Install solvent curing sealants and vapour release adhesive materials in open spaces with ventilation.
- .2 Ventilate enclosed spaces in accordance with Section 01 51 00 - Temporary Utilities.
- .3 Maintain temperature and humidity recommended by materials manufactures before, during and after installation.

1.6 WARRANTY

- .1 For sealant and sheet materials the 12 months warranty period prescribed in subsection GC 32.1 of General Conditions "C" is extended to 24 months.
- .2 Warranty: include coverage of installed sealant and sheet materials which:
 - .1 Fail to achieve air tight and watertight seal.
 - .2 Exhibit loss of adhesion or cohesion.
 - .3 Do not cure.

PART 2 PRODUCTS

2.1 SHEET MEMBRANE AIR BARRIER

- .1 Sheet Seal: Self-adhesive bitumen laminated to high-density polyethylene film, nominal total thickness of 1.0 mm.
 - .1 Membrane Physical Properties

.1	Application	min 5°C
.2	Service Temperature	-40°C to 70°C
.3	Elongation	min 200%
.4	Tensile strength	min 2.4 Mpa
.5	Puncture Resistance	min 178 N
.6	Water vapour transmission	2.8 mg/Pa.s.m ² (0.05 perms)
.7	Moisture Absorption	0.1%
.8	Air Leakage at 75 Pa	0.02 L/Sm ²
.9	Air Leakage of the 3000 Pa test	No Change

2.2 SEALANTS

- .1 Sealants in accordance with Section 07 92 00 - Joint Sealants.
- .2 Primer: recommended by sealant manufacturer.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 GENERAL

- .1 Perform Work in accordance with Sealant and Waterproofer's Institute - Sealant and Caulking Guide Specification requirements for materials and installation.

3.3 EXAMINATION

- .1 Verify that surfaces and conditions are ready to accept work of this section.
- .2 Ensure surfaces are clean, dry, sound, smooth, continuous and comply with air barrier manufacturer's requirements.
- .3 Report unsatisfactory conditions to Departmental Representative in writing.
- .4 Do not start work until deficiencies have been corrected.
 - .1 Beginning of Work implies acceptance of conditions.

3.4 PREPARATION

- .1 Remove loose or foreign matter, which might impair adhesion of materials.
- .2 Ensure substrates are clean of oil or excess dust; masonry joints struck flush, and open joints filled; and concrete surfaces free of large voids, spalled areas or sharp protrusions.
- .3 Ensure substrates are free of surface moisture prior to application of self-adhesive membrane and primer.
- .4 Ensure metal closures are free of sharp edges and burrs.
- .5 Prime substrate surfaces to receive adhesive and sealants in accordance with manufacturer's instructions.

3.5 INSTALLATION

- .1 Install materials in accordance with manufacturer's instructions.
- .2 Over the properly prepared substrate surface apply primer, as per manufacturer's recommendations, with a roller and allow drying to a tacky surface. Prime only area to be covered in a working day. Re-prime area not covered with membrane within 24 hours.
- .3 After primer has dried, using a hand roller firmly press the entire membrane onto the primed surface, in strict accordance with membrane manufacturer's written instructions.

- .4 Ensure complete coverage of and adhesion of all substrates to receive membrane, including wall penetrations. Co-operate with other trades to ensure continuity of membrane.
- .5 Overlap membrane 50mm and carefully smooth out with a roller to ensure full continuous bond throughout overlaps without fissures or fishmounting.
- .6 It is important that a complete air seal be achieved. Be responsible for the completeness of membrane wherever it is not specifically detailed. Consult with Departmental Representative if there is any doubt as to the integrity of membrane, whether detailed or not.
- .7 In order to ensure a complete seal, seal membrane to all penetrations in an approved manner.
- .8 Apply a towelled bead of mastic to all terminations of the membrane at the end of a day's work.
- .9 Do not enclose membrane until it has been inspected and approved by Departmental Representative. Inform Departmental Representative two (2) working days prior to required inspection.

3.6 **CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

3.7 **PROTECTION OF WORK**

- .1 Protect finished work in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Do not permit adjacent work to damage work of this section.
- .3 Ensure finished work is protected from climatic conditions.

END OF SECTION