

CONSTRUCTION LEGEND:

XXXX	DENOTES ROOM NUMBER
	610x610 CEILING TILE
	16mm TYPE 'X' GYPSUM BOARD
	EXISTING CEILING TO REMAIN OR
	OPEN TO STRUCTURE ABOVE

GENERAL NOTES:


- CEILING SPACES BELOW LEVEL 2 TO RECEIVE SPRAY FIRE PROOFING, WHETHER EXPOSED OR ABOVE FINISHED CEILING. (REFER TO SPECIFICATION).
- CEILING GRID/TILES TO BE CENTERED IN ALL ROOMS UNLESS NOTED OTHERWISE. PARTIAL TILES AT ROOM PERIMETERS SHALL NOT BE LESS THAN 100mm IN EITHER DIMENSION.
- ALL SINGLE CEILING ELEMENTS (I.E. LIGHTS, DIFFUSERS, EXIT SIGNS, SMOKE DETECTORS, MISCELLANEOUS DEVICES, ETC.) TO BE PLACED IN CENTER OF CEILING OR CENTER OF GYPSUM BOARD/CEILING AREA UNLESS NOTED OTHERWISE. ALIGN MULTIPLE ITEMS CENTRE OR EDGES.
- SEE ELECTRICAL DRAWINGS FOR THE LOCATIONS OF CEILING MOUNTED SMOKE DETECTORS, EXIT SIGNS, FIRE ALARM DEVICES, ETC. ALSO SEE ELECTRICAL FOR LOCATIONS FOR WALL MOUNTED EXIT LIGHTS.
- SEE MECHANICAL DRAWINGS FOR EXTENT OF EXPOSED DUCTWORK IN EXPOSED STRUCTURE AREAS. PAINT ALL EXPOSED DUCTWORK, PIPING, HANGERS, ETC.
- INSTALL ACCESS PANELS IN NON ACCESSIBLE TYPE CEILING WHERE SERVICE OR ADJUSTMENT TO MECHANICAL, PIPING, OR ELECTRICAL ITEMS MAY BE REQUIRED. ACCESS PANELS SHALL BE EQUAL TO THE RATING OF THE WALL OR CEILING IN WHICH THEY OCCUR.
- 450mm MINIMUM VERTICAL CLEARANCE SHALL BE MAINTAINED BETWEEN THE BOTTOM OF THE EXTENDED SPRINKLER HEADS AND THE TOP OF ANY FILES, SHELVING, LOCKERS, ETC.
- SEE ROOM FINISH SCHEDULE FOR CEILING HEIGHTS IN EACH ROOM AREA. FOR ROOM AREAS DENOTED AS 'X', NEW CEILING TO BE INSTALLED AT SAME HEIGHT AS EXISTING.

FIRE SEPARATION LEGEND:

■■■■■■■■■■ 2 HR FIRE SEPARATION (WALLS AND FLOOR)

FIRE SEPARATION NOTES:

- IN EXISTING FIRE SEPARATION WALLS, FIRE SEPARATION CONTRACTOR TO PROVIDE 2HR FIRE STOPPING TO ALL UNPROTECTED OPENINGS AND PENETRATIONS.
- APPLY SPRAY-APPLIED FIRE PROOFING TO UNDERSIDE OF ENTIRE SECOND FLOOR STRUCTURE BETWEEN GRIDS 2 AND 19 TO ACHIEVE 2 HOUR FIRE RESISTANCE RATING.
- INSPECT AND MAKE GOOD FIRE RATING FOR ALL EXISTING CONSTRUCTION.



REFLECTED CEILING PLAN LEVEL 1
SCALE: 1/50
1 A15



CO2	ISSUED FOR TENDER	02/14/2018
CO1	ISSUED FOR TENDER	09/28/2018
revisions		date
project		project
<p>MAINTENANCE GARAGE REHABILITATION ST. ANTHONY AIRPORT</p>		
<p>REFLECTED CEILING PLAN AND FIRE-SEPARATION PLAN LEVEL 1</p>		
designed	N.S.	compu
date	2016.11.22	
drawn	A.M.	desain
date	2016.11.22	
approved	V.S.	approval
date	2016.11.22	
tender		Submission
<p>PROJEC: Project Manager / Administrateur de projets TPSCC project number / no. du projet R.077269.001</p>		
drawing no.		no. du dessin
<p>A15</p>		