

**Fuel Oil Storage Tank System Replacement
Discovery Centre - Gros Morne National Park (GMNP), Newfoundland**

EA011-201497/A

AMENDMENT # 2

ADDENDUM No. 2

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

SPECIFICATION

.1 In the specifications, section 33 56 16, delete clause 2.4.2.3 and replace with new clause 2.4.2.3 to read:

Tank interstitial space leak detection.

- .1 Dual-point hydrostatic sensor with vent riser and cap*
- .2 Operating temperature -25 to +50 deg. C*
- .3 Operating principle – Reed Switch/Float*

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
