181-17131-00

GENERAL NOTES

1. EXISTING LUMINAIRES AND SMOKE DETECTORS (AND OTHER DEVICES WHERE APPLICABLE) SHOWN WITHIN CELLS TO BE DISCONNECTED AND REMOVED TO ALLOW FOR REMOVAL OF EXISTING CEILING STRUCTURE.
2. EXISTING LUMINAIRES AND SMOKE DETECTORS (AND OTHER DEVICES WHERE SHOWN) TO BE RE-INSTALLED AT SAME LOCATION AFTER NEW CEILING INSTALLATION HAS OCCURRED.
3. FIRE ALARM SYSTEM IS TO BE RE-VERIFIED UPON COMPLETION OF EACH PHASE.

1 UPPER CLEARWATER UNIT FLOOR PLAN
1:100

Public Works and Government Services Canada
Travaux publics et Services gouvernementaux Canada

REAL PROPERTY SERVICES
Western Region

SERVICES IMMOBILIERS
Région de l'ouest

wsp

PROFESSIONAL ENGINEER
T.J. MCKENZIE
MEMBER 28743
2019-08-01
YR. MN. DAY
SASKATCHEWAN

Association of Professional Engineers & Geoscientists of Saskatchewan
CERTIFICATE OF AUTHORIZATION
WSP CANADA INC.
Number C0868
Permission to Consult held by:

Discipline	Sk. Reg. No.	Signature
ELECT.	28743	

Revision	Description	Date
4		
3		
2		
1		
0	ISSUED FOR TENDER	AUG. 2, 2019

Client / client

PUBLIC WORKS AND GOVERNMENT SERVICES CANADA

Project title / Projet

CSC-RHQ REGIONAL PSYCHIATRIC CENTRE
2520 CENTRAL AVENUE NORTH
SASKATOON, SASKATCHEWAN

CELL CEILING REMEDIATION

Designed by / Conçu par: **TM**
Drawn by / Dessiné par: **SB**
Approved by / Approuvé par: **TM**
PWGSC Project Manager / Administrateur de Projets TPSGC: **EH**

Drawing title / Titre du dessin

FLOOR PLAN
UPPER CLEARWATER UNIT

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
R.096063	E-3 OF	0

PWGSC - A1 - 841X594

0 10 20 30 40 50 60 70 80 90 100mm

A000