



1. EXISTING LUMINAIRES AND SMOKE DETECTORS (AND OTHER DEVICES WHERE APPLICABLE) SHOWN WITHIN CELLS TO BE DISCONNECTED AND REMOVED TO ALLOW FOR REMOVAL OF EXISTING CEILING STRUCTURE.
2. EXISTING LUMINAIRES AND SMOKE DETECTORS (AND OTHER DEVICES WHERE APPLICABLE) TO BE RE-INSTALLED AT SAME LOCATION AFTER NEW CEILING INSTALLATION HAS OCCURRED.
3. FIRE ALARM SYSTEM IS TO BE RE-VERIFIED UPON COMPLETION OF EACH PHASE.

4		
3		
2		
1		
0	ISSUED FOR TENDER	AUG. 2, 2019
Revised	Description	Date
Client		Client

**PUBLIC WORKS AND  
GOVERNMENT SERVICES  
CANADA**

**Project title** CSC-RHQ REGIONAL PSYCHIATRIC CENTRE  
2520 CENTRAL AVENUE NORTH  
SASKATOON, SASKATCHEWAN

## CELL CEILING REMEDICATION

Designed by	Conce. par
TMA	
Drawn by	Dessiné par
SB	
Approved by	Approuvé par
TMA	
PMISOC Project Manager	Administrateur de Projets TPISOC
EH	

**FLOOR PLAN**  
**ASSINIBOINE UNIT**

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
R.096063	E-1 OF	0