



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Assainissement de sols contami	
Solicitation No. - N° de l'invitation EZ897-201126/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2019-10-23
GETS Reference No. - N° de référence de SEAG PW-\$PWY-039-8673	
File No. - N° de dossier PWY-9-42090 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-10-29	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Park (PWY), Isabell	Buyer Id - Id de l'acheteur pwy039
Telephone No. - N° de téléphone (604) 365-0073 ()	FAX No. - N° de FAX (604) 775-9381
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Former Trutch Townsite K19 – Alaska Hwy, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

Amendment 003

This amendment is issued to:

1. extend the closing date; and,
2. publish Q & A.

On Page 1,

Remove:

Solicitation Closes - L'invitation prend fin
at - à 02:00 PM
on - le 2019-10-25

Time Zone
Fuseau horaire
Pacific Daylight Saving Time PDT

Insert:

Solicitation Closes - L'invitation prend fin
at - à 02:00 PM
on - le 2019-10-29

Time Zone
Fuseau horaire
Pacific Daylight Saving Time PDT

Questions and Answers

Question #1:

Is the material from the Adsette Highways Pit available and suitable as per the tender specifications for use at the K19 site as backfill?

Answer #1:

A portion of the backfill can be sourced from Adsette Pit. Please see the revised Unit Price Table for estimated Backfill-Owner Supplied volumes that include Adsette Pit and the Trutch Rock Quarry. Analytical results for the suitability of the backfill are pending and an update will be provided if they are deemed to be unsuitable.

Question #2:

Can you confirm whether a weigh scale is required on-site for the excavation of contaminated soil ? Or can the contaminated soil disposal centre supply the weigh slips?

Answer #2:

A weigh scale is not required on-site. The Disposal Facility must supply the weigh slips as part of the measurement procedure for Contaminated Soil Transport and Contaminated Soil Disposal. The weigh scale is to be certified by Measurement Canada. Please refer to Division 02 61 00.05 Section 1.1.1.

Question #3:

Is a weigh scale necessary for the backfill area and material?

Answer #3:

A weigh scale certified by Measurement Canada is required for the measurement Backfill-Imported. Please refer to Division 02 61 00.02 Section 1.1.3. The measurement of Backfill-Owner Supplied will be by surveyed volume. Please refer to Division 02 61 00.02 Section 1.1.5.

Question #4:

Can you confirm the source of the imported backfill and location? Can you confirm the pricing on the backfill (for ex. per tonne)?

Answer #4:

The source and pricing of the Backfill-Imported is up to the Contractor to determine. The sources of the Backfill-Owner Supplied are the Trutch Rock Quarry and Adsette Pit. Please refer to the revised Unit Price Table for volume estimates.

The Trutch Rock Quarry is located approximately 5 km south of the site on Mile 202 Road. Adsette Pit is approximately 49 km north of the site in Prophet River, BC (km 366).

Question #5:

Can a drawing and /or instruction be provided that details the location of the additional area's at the site to be backfilled?

Answer #5:

The open excavation at AEC 1C is to be backfilled with approximately 8,492 tonnes of backfill. Please refer to the table on Drawing 3 – Contaminated Soil Extents.

Question #6:

Based upon the time of year that the work is being proposed can the specification for the supply and placement of topsoil and grass seed be removed from the tender?

Answer #6:

No. A winter seed mix will be used to reduce the risk of weed establishment.

Question #7:

Can a more specific spec be provided for the grass seed required?

Answer #7:

The following seed mix is recommended:

Blend	Seed
30.0%	Slender Wheatgrass
15.0%	Fringed Brome (ultracoat)
12.0%	Tufted Hairgrass
10.0%	Northern Wheatgrass
15.0%	Diploid Annual Ryegrass
7.0%	Fowl Bluegrass
10.0%	Sloughgrass
1.0%	Bluejoint Reedgrass

Use the following application rates:

Drill/Brillion = 15 kg/ha (13.38 lbs./acre)

Broadcast = 30 kg/ha (26.76 lbs./acre)

Hydroseeding = 100 kg/ha (89.22 lbs./acre)

All other terms and conditions remain unchanged.