



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Harbour Repairs	
Solicitation No. - N° de l'invitation F1571-198017/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F1571-198017	Date 2019-10-31
GETS Reference No. - N° de référence de SEAG PW-SPWY-028-8681	
File No. - N° de dossier PWY-9-42089 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-11-06	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Park, Isabell	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 365-0073 ()	FAX No. - N° de FAX (604) 775-9381
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Tofino Small Craft Harbour-Armitage Point & Wingen Lane – Tofino, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The Solicitation Amendment 002 is raised to issue Addendum 002.

Please be reminded to submit the revised Bid and Acceptance Form (BA) and the revised Combined Price Form found in Solicitation Amendment 001 when submitting your bid package. Failure to submit these completed forms with your bid may result in your bid being disqualified.

Please see Addendum 002 herein.

All other terms and conditions remain unchanged.

Addendum 002

**The following changes/clarifications in the tender documents are effective immediately.
This addendum will form part of the contract documents.**

Addendum 002 is raised to:

1. Provide answers to bidder questions

Q1) Looking at the plans for Armitage it appears the majority of the stringers are to be roughly 32 ft in length which is difficult but possible.
However a few are upwards of 60 the question is will splicing shorter 6x12s in these areas be acceptable?

A1) This is acceptable, so long as that stringers span a minimum of 2 bents.

Q2) All of the materials for these piers are in accordance with AWPA / ACZA standards except for the 2 creosote caps and the crossbraces.
The question is can the creosote caps be substituted for ACZA 6.4 which is also in accordance with AWPA standards or even 30 kg which well exceeds AWPA standards?

A2) The use of ACZA 30Kg is an acceptable alternative for these members.

Q3) The cross bracing at both sites calls for 14 lb. /225 m3 creosote for marine immersion in accordance with AWPA standards the question is can the cross barces be substituted for 1.9 lb or 30 kg ACZA which is also in accordance with AWPA and CSA stantards

A3) The use of ACZA 30Kg is an acceptable alternative for these members.

End of Addendum 002