

# AMENDMENT #2 REQUEST FOR PROPOSAL (RFP)

## UPS Maintenance services for the David Florida Laboratory in Ottawa

### Bid Submission Deadline: November 1st, 2019 at 2:00 PM (EDT)

#### Submit Bids to: Canadian Space Agency TENDERS RECEPTION OFFICE Monday to Friday Receiving/Shipping (8:00 to 16:30)

Closed between 12:00 and 13:00 6767 route de l'Aeroport Saint-Hubert (Quebec) J3Y 8Y9, Canada

# **Or by E-Post Connect**

### Reference: CSA File No. 9F030-20190305

*Note*: Please read this Request for Proposal carefully for further details on the requirements and bid submission instructions.



October 30, 2019



#### Amendment #1

#### The Request for Proposal 9F030-20190305 is hereby amended as follows:

#### 1) Answer the following questions :

	Questions (English)		Answers		
7.	Can you kindly confirm the KVA and number of batteries for the three UPS:		Please note that the batteries in the two Eaton 9355-15 units will be replace prior to contract start, so the		
	UPS Eaton 9355-15 Eaton 9355-15 Eaton 9355E-140	Serial Number bc062jba04 be012jba01 bk395lxx03	requirement to replace the batteries in the RFP will occur in year 5 of the new contract.		

UPS	Serial Number	<b>KVA</b>	
Eaton 9355-15	bc062jba04	<mark>15</mark>	
Eaton 9355-15	be012jba01	<mark>15</mark>	
Eaton 9355E-140	bk395lxx03	<mark>40</mark>	

#### **Battery Information / Informations sur les batteries:**

UPS	Serial Number
Eaton 9355-15	bc062jba04
Eaton 9355-15	be012jba01

# **Battery Information**

Manufacture I	Universal	Battery
---------------	-----------	---------

Batter	y Model	UB1290k
--------	---------	---------

# of Strings	4	Trays/Str	2	Jars/T	ray <b>8</b>
Date Code		OCT-2015		Age	4
Battery Type	Sealed	Batte	ry Cabir	net Type	INTERNAL TO

Eaton 9355E-140

bk395lxx03

Battery Information						
Manufacture	Eaton					
Battery Model 93E B		ttery Trays				
# of Strings	8	Trays/Str	2	Jars/T	ray	9
Date Code		2017		Age	3	
Battery Type	Battery		/ Cabinet Type		INTERNAL TO	