



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Half Island Cove Harbour Imp Proj.	
Solicitation No. - N° de l'invitation EB144-201588/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EB144-20-1588	Date 2019-11-12
GETS Reference No. - N° de référence de SEAG PW-SPWA-122-5944	
File No. - N° de dossier PWA-9-82058 (122)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-11-19	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Chinye (PWA), Chukwudi	Buyer Id - Id de l'acheteur pwa122
Telephone No. - N° de téléphone (902) 401-7604 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

La question et la réponse ci-dessous ne sera disponible qu'en anglais, en raison de la nature technique.

La modification 002 vise à clarifier la réponse à la question dans la modification 001.

Question 1: With regards to the existing concrete deck & crib work:

In the General Instructions, Section 01 29 00 Project Particulars & Measurement, Page 2, Paragraph 4 Under Measurement for Payment, it states that **Removal & Proper Disposal** of the (existing) concrete deck and cribwork is included.

However, on the drawings, it states that the existing concrete deck can be collapsed into the existing cribwork to fill voids.

Can you please confirm what is to be done with the concrete & steel in the existing concrete deck/walls, as well as the existing cribwork above elevation +2.3m, which is to be demolished.

Answer to Question 1: C Correct, it is permissible to leave the demolished concrete in place provided that it stays within the footprint of the existing cribwork. If the concrete is to be removed from the existing footprint, then it must be disposed of as per the contract specifications, specifically Section 31 11 00.

Toutes les autres modalités et conditions demeurent les mêmes.