




Last saved by: SOLTYS(2019-09-30) Last Plotted: 2019-09-30
Filename: P:\60577665\900-CAD_GIS\910-CAD\20-SHEET\SCIDES\IGNTUNNEL_43\C1.09 - DETAIL.DWG


PWSC - A1 - 841X94




TERMINOLOGY



CLASS A BEDDING
(CONCRETE BACKFILL & BEDDING)



BEDDING DETAILS



WATER MAIN
BEDDING DETAILS





NOTES:

1. W (TRENCH WIDTH) = O.D. + 600mm (MINIMUM), O.D. = OUTSIDE DIAMETER
2. d = DEPTH OF BEDDING BELOW PIPE;
I.D. = 750mm OR SMALLER, d MIN = 100mm
I.D. = 750mm TO 1500mm, d MIN = 100mm
I.D. = 1650mm AND LARGER, d MIN = 150mm
I.D. = INSIDE PIPE DIAMETER
3. BEDDING UNDER THE MIDDLE THIRD OF THE PIPE SHALL BE LOOSE, UNCOMPACTED MATERIAL.
4. IF A ROCK FOUNDATION, THEN MINIMUM BEDDING THICKNESS IS Do/24.

1 | PIPE BEDDING
Scale 1:10

SAFE BEARING LOADS	
SOIL TYPE	SAFE BEARING LOAD (kPa)
SOFT CLAY	100
SAND OR HARD CLAY	250
SAND AND GRAVEL	400
SAND, GRAVEL CEMENTED WITH CLAY	500
SHALE (UNDISTURBED)	1000


THRUST BLOCKS





SAMPLE CALCULATIONS

FOR WORKING PRESSURE OF 690 kPa AND Ø 200 PIPE
AT 90° BEND (0.062 m²) IN SOFT CLAY (100 kPa)
AREA REQUIRED = $690 \times 0.062 = 0.427 \text{ m}^2$
100

WORKING PRESSURE (kPa)		SIZE OF VALVE REQUIRING ANCHORAGE
345	690	300 AND UP
690	1035	200 AND UP
1035	1380	ALL SIZES




GATE VALVE ANCHORS




2 | REACTION BLOCKING AND ANCHORAGE
Scale 1:10

TENDER
NOT FOR CONSTRUCTION



Key Plan



Revision	Description	Date
E	Issued For Tender	19/09/30
D	Issued For 99% Review	19/06/21
C	Issued For 85% Review	19/03/15
B	Issued For 50% Review	18/11/13
A	Not Issued	18/09/07

Public Works and
Government Services Canada

Project title

Tunnel Revitalization

Designed by
C. Cunningham

Drawn by
G. Soltys

Approved by
B. Wolfater

PWSC Project Manager
J. Dayman

Drawing title

Package 1 - TBU43

Civil
Details

Project no.	Drawing no.	Revision no.
1004259	C1.09	E