



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Cheboque Wharf Reconstruction	
Solicitation No. - N° de l'invitation EB144-201786/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EB144-20-1786	Date 2019-12-05
GETS Reference No. - N° de référence de SEAG PW-SPWA-122-5952	
File No. - N° de dossier PWA-9-82060 (122)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-12-10	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Chinye (PWA), Chukwudi	Buyer Id - Id de l'acheteur pwa122
Telephone No. - N° de téléphone (902) 401-7604 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 003 is raised to answer the question and incorporate the change below

Question 1: On drawing S4 detail “F”, it show timber cross bracing (X brace). Does Canada want them on row B, C, D or just on C? This does change the quantity by quit a lot.

Response to Question 1: As shown on S3, section D and E, The S4, Detail F, is only on Line ‘C’.

See amended electrical scope:

Specification section 26 56 20 2.1.1.1

Delete reference to 168 watts. Voltage and distribution to remain.

Revise Light Input 125 - 170 watts.

Add : “Lumen Output - Minimum 20,000 to Maximum 24,000”

Add: “Efficacy (LPW): 135 lumens – 165 lumens”

All other parameters to remain unchanged.

All Other Terms and Conditions remain the same.