

ABOVEGROUND HEATING OIL STORAGE TANK (AST)

Maintenance / Inspection Checklist

Canadian Forces Housing Agency's Maintenance and Minor Improvements Standing Offer Document 2020-2024

Address- Street: Bldg.nº : Sub Bldg. nº :

Date Serviced : DAY/MTH/YEAR Work Order nº :

AST Information:

Year Installed: Make: Model nº: Serial nº:

Location: Size: (Litres) Material: (fiberglass or steel)

Double walled: (Yes or No) Feed: (Bottom or Side)

Items to be serviced or inspected:

Check and Populate applicable box(es) N/A = Not Applicable; C = Completed; A/R = Action Required

		N/A	C	A/R	Describe Action Required:
1.	AST and lines – inspected				
2.	Sight/level gauge – inspected and adjusted				
3.	Vent whistle – inspected				
4.	Fuel filter – replaced				
5.	Legs/anchoring – inspected and stable				
6.	Clearances to combustible materials – inspected				
7.	Lines protection – inspected				
8.	Secondary containment/Spill protection device – inspected				
9.	Fill and vent pipe – inspected				
10.	Tank condition – inspected and touch up				
11.	ULC tag – inspected				
12.	Shut off valve(s) – inspected and tested				
13.	Presence of water – inspected and noted				
14.	AST protected from vehicle impact – inspected				
15.	AST Conforms to applicable codes – inspected				

Occupant's information: (write "VOID" if RHU is vacant) Contractor's information:

Occupant's name: Technician's name:

Occupant's signature: Certificate nº:

