



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:**

Bid Receiving/Réception des soumissions
RCMP/GRC
Attention: Candice Therien – Procurement &
Contracting Services
Mailstop/Arret postal 15
73 chemin Leikin Drive,
Ottawa, ON K1A 0R2

All persons delivering mail, parcels and bids to the Mail Parcel and Screening Facility will be asked to provide government photo identification and a contact number as part of an enhanced security protocol. / Dans le cadre d'un protocole de sécurité amélioré, toute personne qui livre le courrier, les paquets et les soumissions à l'installation d'inspection du courrier et des colis devra désormais présenter une carte d'identité avec photo émise par le gouvernement et un numéro de téléphone

**SOLICITATION
AMENDMENT**

**MODIFICATION DE
L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments: - Commentaries :

Title – Sujet Interconnecting Furniture Panels		Date December 23rd, 2019
Solicitation No. – N° de l'invitation 202000790/B		Amendment No. – N° de la modification 003
Client Reference No. - No. De Référence du Client 202000790		
Solicitation Closes – L'invitation prend fin		
At / à :	2 :00 PM	EST(EasternStandard Time) HNE (heure normale de l'Est)
On / le :	January 7th, 2020	
Delivery - Livraison	Taxes - Taxes	Duty – Droits
Destination of Goods and Services – Destinations des biens et services		
Instructions See herein — Voir aux présentes		
Address Inquiries to – Adresser toute demande de renseignements à Candice Therien (Candice.therien@rcmp-grc.gc.ca)		
Telephone No. – No. de téléphone 613-843-3826	Facsimile No. – No. de télécopieur 613-825-0082	

Delivery Required – Livraison exigée	Delivery Offered – Livraison proposée
Vendor/Firm Name, Address and Representative – Raison sociale, adresse et représentant du fournisseur/de l'entrepreneur:	
Telephone No. – No. de téléphone	Facsimile No. – No. de télécopieur
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) – Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date



This amendment is raised to address the following:

- To respond to questions received during the solicitation period
- To revise the solicitation accordingly. As applicable

QUESTIONS AND ANSWERS

QUESTION 1: The floor plan is showing powered panels with electrical duplexes on panels that are 30" w in the central spine of the workstations, and even though the 24" wide panels don't require receptacles, they still require power in order to feed the other panels but Annex B is not showing any 24" wide nor 30" wide powered panels. Are suppliers to price as per Annex B or should this annex be amended to reflect power on these panels?

ANSWER 1: The 24" panels do not require an electrical outlet however the supplier will have to provide an electrical jumper as required to continue with power.

QUESTION 2: Can you confirm if top feeds or base feed are required?

ANSWER 2: Base feeds are required.

QUESTION 3: Please identify on the floor plan where the top and/or base feeds are located? Suppliers need to know in order to provide an accurate hardware count?

ANSWER 3: See attachment – the electrical drawing E200 Ground floor plan Power and Fire Alarm system and E300 Ground Floor Communications Layout

QUESTION 4: Are voice and data outlets to be supplied as part of the interconnected panels or just the opening and cover plate to house the voice and data outlets?

ANSWER 4: Voice and Data outlets are being supplied by other firms. You are only to supply an opening and cover plate.

QUESTION 5: Pls. clarify- are you saying you want to power 9 stations, 3 duplexes each on one feed? That would be 54 plug in points on one feed.

ANSWER 5: Please find attached electrical drawing E200 Ground floor plan Power and Fire Alarm system and E300 Ground Floor Communications Layout that show where the grommets are located in the raised floor and the detailed power requirements per work station. We are expecting 1 circuit per workstation (1 seat) with up to 5 duplex outlets around. Refer to attached Drawing E200 and detail. If less power cable pass-through for multi-workstation grouping can be accommodated, this would be better. Less holes in raised floor.



QUESTION 6: Please clarify- Tender states each station to have two triplexes or three duplex outlets. If these are all on one circuit per station how can one feed supply 9 circuits- as stated above one feed is to supply 9 stations.?

ANSWER 6: See above reply.

QUESTION 7: What is the panel matrix? Are you conforming to Workplace 2.0 for the base ht.36 inches high?

ANSWER 7: No we are not following Work Place 2.0 Standard heights.

QUESTION 8: What heights do you require for add-ons so all bidders will be bidding on the same criteria?

ANSWER 8: There are no add-ons since we are not following Workplace 2.0 standards. The panel heights are to be 66"

QUESTION 9: What is meant by "Resource Input? Please clarify.

ANSWER 9: This reference can be deleted.

QUESTION 10: Are copper cabling to be hidden in panel RFP up to desk? Refer to detail attached'.

ANSWER 10: Furniture supplier can provide opening at desk level to pull out copper/fibre cables above desk to MUTOAs.

SOLICITATION REVISIONS

- 1) The solicitation closing date is extended to January 7th, 2020 as indicated on page 1 of this amendment. The tender notice at <https://buyandsell.gc.ca/procurement-data/tender-notice/PW-19-00896993> will be revised accordingly.