



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Pacific Region
401 - 1230 Government Street
Victoria, B.C.
V8W 3X4
Bid Fax: (250) 363-3344

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
401 - 1230 Government Street
Victoria, B. C.
V8W 3X4

Title - Sujet Potassium Acetate Tanks	
Solicitation No. - N° de l'invitation W0133-20T010/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client W0133-20T010	Date 2020-01-09
GETS Reference No. - N° de référence de SEAG PW-\$VIC-256-7862	
File No. - N° de dossier VIC-9-42136 (256)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-01-27	
Time Zone Fuseau horaire Pacific Standard Time PST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Morton, Chris	Buyer Id - Id de l'acheteur vic256
Telephone No. - N° de téléphone (250) 580-1311 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT

Solicitation Amendment 001 is issued to address bidder enquiries and adjust the mandatory technical criteria. The solicitation closing date will be extended to 27 January 2020.

At Page 1, Solicitation closes:

DELETE: 2020-01-22 at 02:00 PM Pacific Standard Time PST

INSERT: 2020-01-27 at 02:00 PM Pacific Standard Time PST

Bidder Enquiries:

Q1: Will the tank be used for de-icing applications on a truck?

A1: No.

Q2: Should the requested tank be rectangular cross section, or is a cylindrical tank also acceptable?

A2: A cylindrical design is preferable to allow a possible mounting onto the frame of a sea container. However, this is not mandatory.

Q3: Please state the type of pump required, as well as flow rate and pressure head required?

A3: Electric is preferred, as the current tanks are electric. However, this is not mandatory. The flow rate will be based on where the pump is mounted. The pump will need to be a minimum of 2hp.



Annex D, Article 15 is being revised to add mandatory pump pressure requirement (new Article 15).

Q4: Is a vertical tank acceptable? The double-walled potassium acetate tanks are usually vertical. If you ask for a horizontal tank, the tank should be customized and needs drawings to be built. Please provide any drawings regarding the requested tank if the vertical unit is not acceptable.

A4: Horizontal tanks are preferred, as it allows for possible tank movement in the future. However, this is not mandatory.



Annex "D", Article 1 is being revised to remove the mandatory horizontal design requirement.



Drawings are not available, however the photo below illustrates a horizontal tank design of an approximate size to what is required.



Annex "D" – Mandatory Technical Criteria:

At Page 14, Mandatory Technical Criteria:

DELETE: Annex "D" in full.

INSERT: Annex "D":

In their bid submission, Bidders must demonstrate how they meet all requirements detailed in the Requirement at Annex "A" and address clearly and in sufficient depth all points that are subject to evaluation criteria listed below against which the bid will be evaluated. Bidders should demonstrate their capability and describe their approach in a thorough, concise and clear manner for carrying out the work.

The Bidder must provide proof and/or verification of the Mandatory Evaluation Criteria herein through supporting documentation, as applicable. Bidders are required to provide a page reference number by each compliant requirement that refers to the supplied literature; if left blank, it may be evaluated as not met. It is the Bidder's responsibility to ensure that the submitted supporting documentation provides detail to prove that the proposed good(s) meet the requirements of the mandatory criteria. If published supporting documents or certifications are not available, Bidders should prepare a written narrative complete with a detailed explanation of how its bid demonstrates technical compliance.

Canada will not evaluate information such as references to website addresses where additional information can be found, or technical manuals or brochures not submitted with the bid. To be considered responsive, proposals must meet all of the mandatory criteria specified in the solicitation document.

	ARTICLE	MINIMUM MANDATORY CRITERIA	BIDDER'S COMMENTS/RESPONSE	LOCATION IN BID WHERE CRITERIA IS ADDRESSED
NEW	1	Must be 20,000 litre (minimum) double-walled container tanks.		
	2	Tanks must be built to ISO container dimensions.		
	3	Tanks must be moveable and stackable with forklift capability and proper forklifting pockets.		
	4	Must have corner twist locks for ease of handling and transport.		
	5	Tanks must be constructed with material sufficient to hold potassium acetate. Internal finish (if required) to be compatible with Safeway KA Hot Blue Runway De-icer.		
	6	Must have product level gauge (sight glass or contents meter).		
	7	Transfer pump must be a self-contained pumping system.		
	8	10.16cm (4") cam lock - inlet bulk transfer system.		
	9	5.08cm (2") cam lock - output bulk transfer system.		
	10	7.62m (25'), 5.08cm (2") and 10.16cm (4") hoses for receiving and issuing of product.		
	11	Secondary containment. Tanks must have double walls providing 110% containment.		
	12	Manhole access for inspection and maintenance of inner tank.		
	13	Double manifold in order to plumb the two tanks together.		
	14	Valve, tank and hose protection. Barrier or posts to protect and prevent equipment impact with storage facility.		
NEW	15	Pump must be a minimum of 2hp.		
	16	Tank Maintenance and installation manuals in English; and		
	17	Two-year manufacturer's warranty against manufacturers' defects.		

All other terms and conditions remain the same.