



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Box/Boîte de Réception des
Soumissions
1st Floor/1^{ère} étage, Suite 1212
100-1045 Main Street
Moncton
New Brunswick
E1C 1H1
Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Acquisitions NB/PEI (Moncton Office) – Bureau
d'acquisitions N.-B./Î.-P.-É. (Moncton)
1045 Main Street / 1045, rue Main
Moncton
New Bruns
E1C 1H1

Title - Sujet Reparation/pavillon de bain, Fundy	
Solicitation No. - N° de l'invitation EC373-202055/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client EC373-202055	Date 2020-01-09
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-003-5659	
File No. - N° de dossier PWJ-9-42098 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-01-14	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Young (PWJ), Leesa	Buyer Id - Id de l'acheteur pwj003
Telephone No. - N° de téléphone (506) 871-1716 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Modification No 006 à l'invitation à soumissionner

Titre : Remise en état du pavillon de bain de la piscine Fundy - Fundy (N.-B.)

Cette modification à l'invitation numéro six (006) est soumise pour inclure l'addenda numéro 06 suivant.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat. Toutes autres conditions ne changent pas.

Questions et Réponses:

- Q: In regards to the window sashes we cannot find what paint to use , calling for oil based paint that is no longer available.
A: The linseed oil paint as specified in the standard of acceptance is available from specialty paint suppliers. Please price as specified.
- Q: We suggest removing the full mortar bed as during the chipping of tile most of this will be damaged and are worried that all will have to be replaced. Please clarify what you want to have done.
A: We will not be changing our approach at this time. Please price as designed/ specified.
- Q: For the wall tile we understand not wanting to choose a colour but a size and shape is needed in order to price this piece of work as this greatly effect cost of material and labour to install.
A: Please refer to Addendum 02.
- Q: For heritage doors and windows is there any further information that can be given of the original materials used.
A: There are no records or information available on the original materials at this time.
- Q: We suggest using a stainless steel ring nail for roofing purposes as this will give you a much longer life span.
A: Please price as specified.
- Q: For the door going into the basement are we to allow for any cost for fixing the concrete as it is severely cracked and could be further damaged by removing the frame.
A: This will be addressed in a future phase of work. Please price as designed.
- Q: Are we to fix any of the mortar joint on the exterior stone or the cracked concrete in various locations.
A: This will be addressed in a future phase of work. Please price as designed.

- Q: Where to do the hangers of the basement equipment attach to and will replacement need to occur for these locations. We also noticed that the spacing of the hangers would probably not meet code requirements.
A: Please refer to Detail 2, M-1 Ventilation Drawing for information on methods and extent of equipment to be hung.
- Q: In what shape is the Structural steel and should we allow for any misc. metal repairs?
A: Condition unknown and not in the scope work.
- Q: Are we to allow for fire collars at locations where penetrations through the slab occur or is just firestopping sufficient?
A: Please refer to the requirements outlined in section 07 8400, part 1.5 of the specification.
- Q: Is there any finish on the OWSJ which would require additional work in order to properly fireproof?
A: Unknown at this time. Fireproofing to be installed per the requirements of the manufacturer.
- Q: Do we have to fill any voids where electrical and plumbing has penetrated the electrical room?
A: No.
- Q: The door in the electrical room would not meet current fire code standards should we allow for replacement of this door?
A: No. This door is heritage and not in the scope of work.

N° de l'invitation - Solicitation No.
EC373-202055/A
N° de réf. du client - Client Ref. No.
R.087633.001

N° de la modif - Amd. No.
006
File No. - N° du dossier

Id de l'acheteur - Buyer ID
PWJ003
N° CCC / CCC No./ N° VME - FMS

- Q: Do we have too actively heat the building throughout construction or does this only have to be done as we require?
A: All products to be installed per manufacturers requirements. Heating requirements to suit.
- Q: On drawing A-4 finish schedule two types of ep[oxy are listed EF 01 epoxy floor and EF 02 epoxy non slip but drawing A11 has an added type EF 03 with no added information on type. Please clarify.
A: EF 03 indicates locations of a secondary non-slip colour.
- Q: What is the Species of the wood frames and is it possible to have a detail relating to this piece of work?
A: Species of wood is unknown, no records exist.

Toutes les autres conditions de l'invitation à soumissionner demeurent inchangées.

Toute question relative à cette modification doivent être adressées à :

Nom: Leesa Young
1045, rue Main
Moncton (N.-B.), E1C 1H1
N° de téléphone: (506) 871-1716
N° de télécopieur: (506) 851-6759
Courriel: leesa.young@pwgsc-tpsgc.gc.ca