



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Box/Boîte de Réception des
Soumissions
1st Floor/1^{ère} étage, Suite 1212
100-1045 Main Street
Moncton
New Brunswick
E1C 1H1
Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Acquisitions NB/PEI (Moncton Office) – Bureau
d'acquisitions N.-B./Î.-P.-É. (Moncton)
1045 Main Street / 1045, rue Main
Moncton
New Bruns
E1C 1H1

Title - Sujet Reparation/pavillon de bain, Fundy	
Solicitation No. - N° de l'invitation EC373-202055/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client EC373-202055	Date 2020-01-10
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-003-5659	
File No. - N° de dossier PWJ-9-42098 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-01-16	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Young (PWJ), Leesa	Buyer Id - Id de l'acheteur pwj003
Telephone No. - N° de téléphone (506) 871-1716 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Modification No 007 à l'invitation à soumissionner

Titre : Remise en état du pavillon de bain de la piscine Fundy - Fundy (N.-B.)

Cette modification à l'invitation numéro sept (007) est soumise pour inclure l'addenda numéro 07 suivant.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat. Toutes autres conditions ne changent pas.

Cette modification est émise pour :

Référence: **Date de clôture apparaissant à la première page du document**

SUPPRIMER la date de clôture de l'invitation à soumissionner du **2019-01-14**; et

INSÉRER à la date de clôture de l'invitation à soumissionner révisée du **2020-01-16**

Cette modification est émise pour publier les addendum ci-inclus.

(1) Addendum # 003

Questions et Réponses:

- Weather-stripping "sprung bronze V-type and sprung bronze with thick felt between moving components" is no longer available. This product called CL1 TL1 was supplied by a Quebec based company that is no longer in business. Is there an approved alternate we could use?
A: There are alternate equivalent products on the market. Final product alternatives will be reviewed during the shop drawing process.
- Q: All the conduit in basement which is to be removed for fireproofing to be put into a table tray or to be rehanged?
A: Refer to Addendum 03.
- Q: For the Corian Solid surfacing product you should choose a colour as the price varies from 160 Ft² - 260 Ft² and if none is chosen we will assume the most expensive colour will be used.
A: Refer to Addendum 03 revision.
- Please clarify the make-up of the roof, as in detail 2 of page A-14 shows vertical strapping to be used but this is omitted in all the other details shown on this.
A: Refer to Addendum 03.
- All the conduit in basement which is to be removed for fireproofing to be put into a table tray or to be rehanged?
A: Refer to Addendum 03.

Toutes les autres conditions de l'invitation à soumissionner demeurent inchangées.

Toute question relative à cette modification doivent être adressées à :

Nom: Leesa Young

1045, rue Main, Moncton (N.-B.), E1C 1H1

N° de téléphone: (506) 871-1716, N° de télécopieur: (506) 851-6759

Courriel: leesa.young@pwgsc-tpsgc.gc.ca

1.1 ADDENDUM

- .1 The following changes and clarifications to the drawings and specifications are to be incorporated in the tender documents:

.1 Specifications:

- .1 Section 06 20 00 – Finish Carpentry
.1 2.7.1.1 Revise to read: "Colour: Corian Private Collection, Whipped Cream."
- .2 Section 08 71 00 – Door Hardware
.1 2.2.5 Add to read: "Exterior Door Levers:
.1 Lever Sets: 124mm long x 60 mm projection, 26 mm clearance.
.2 Rosette: Existing heritage rosette To be cleaned and re-instated.
.3 Acceptable materials: Emtek Montrose Sandcast Bronze Lever. Finish to be selected from manufacturer's complete finish range."
.2 2.2.6 Add to read: "Latch-Style Door Hold-Open:
.1 Standard of Acceptance: Ives FS446 Floor Stop & Manual Door Holder.
.2 Finish to be selected from manufacturer's complete finish range."
.3 3.1.9 Add to read: "Where thumb pulls are to be replaced with levers at exterior doors, existing deadbolt and rosette trims to remain. Repairs and cleaning per architectural drawings."
.4 3.1.10 Add to read: "Existing thumb pull and redundant rosette to be returned to Departmental Representative."
.5 3.1.11 Add to read: "Existing rosette to be reinstated with new lever."
.6 3.1.12 Add to read: "Patch and repair all redundant hardware openings in door leaf per the requirements of Section 08 03 52 Conservation Treatment for Period Windows and Doors."
.7 3.7.7.3 Add to read: "Latch-style door hold-open."
.8 3.7.8 Add to read: "Group 09 (Front Entrance Doors):
.1 Barrier-free door operators
.2 Door lever (passage)"
- .3 Section 09 67 70 – Epoxy Flooring
.1 Replace entire section.
.2 2.1.3.3 Formerly 2.1.6.3.
.3 2.1.4.3. Formerly 2.1.7.3.
- .4 Section 22 42 01 – Plumbing Specialties and Accessories
.1 2.7. Add Section 2.7 Hydration Station (HS-1)

.2 Drawings:

- .1 A-2 Main Level New Construction Plan
.1 Replace drawing in its entirety.



- .2 A-7 Enlarged Plan + Interior Elevations
 - .1 Replace drawing in its entirety.
- .3 A-12 Door Schedule + Door Elevations
 - .1 Replace drawing in its entirety.
- .4 Detail #2/A-14 Typical Roof Details
 - .1 Delete note: "New 38 mm x 100 mm pressure treated vertical strapping."
- .5 M-2 Sanitary
 - .1 Replace drawing in its entirety.
- .6 M-3 Water Piping
 - .1 Replace drawing in its entirety.
- .7 E-1 Power Plan, Communications, & Legend
 - .1 Add: Electrical Contractor shall temporarily remove existing basement ceiling conduit, cable, boxes, supports, devices, and lighting to remain in coordination with ceiling modifications. Provide temporary support and protect from damage during construction. Re-install upon completion of ceiling work, supply and install additional hangers, strut, etc. as required to secure to new ceiling. Electrical Contractor shall test and verify proper functionality and continuity of existing circuits upon completion of reinstallation.
 - .2 Add: Supply and install two (2) GFCI receptacles and new 15A circuit for water bottle fill stations. Feed from spare breaker new panel NP. Coordinate final location with mechanical.
- .3 Clarifications:
 - .1 Refer to drawing M-1 Ventilation and Section 20 05 29 – Hangers and Supports for Piping and Equipment for requirements for ventilation equipment hangers.
 - .2 Drawing E-1 Power Plan, Communications, & Legend: Conduit and cable in basement made obsolete by removals of main floor equipment and circuits shall be removed in its entirety.

END OF SECTION