



TENDER AMENDMENT

RETURN BIDS TO:

Procurement Hub
Fisheries and Oceans Canada
200 Kent Street
Ottawa, ON
K1A 0E6

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Procurement Hub
Fisheries and Oceans Canada
200 Kent Street
Ottawa, ON
K1A 0E6

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Centre d'approvisionnement
Pêches et Océans Canada
200 rue Kent
Ottawa (ON)
K1A 0E6

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Centre d'approvisionnement
Pêches et Océans Canada
200 rue Kent
Ottawa (ON)
K1A 0E6

Title: Ile d'Entrée, Îles-de-la-Madeleine – Slipway Construction and Breakwater Repair		
Solicitation No.: / N° de l'invitation : FP802-190296	Amendment No.: / N° de modification de l'invitation : 001	Date: January 14, 2020
Client Reference No. / No. de référence du client(e) F3731-190009		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: January 29, 2020	Time Zone: EST (Eastern Standard Time)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : 343-542-5840	Email Address: / Courriel : nicole.levesque-welch@dfo-mpo.gc.ca	
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 001

This amendment is being raised to extend the bid closing date and to respond to questions submitted in response to solicitation FP802-190296:

A. BID CLOSING DATE

The closing date for tender FP802-190296, titled Ile d'Entrée, Îles-de-la-Madeleine – Slipway Construction and Breakwater Repair, is extended from January 22, 2020 until January 29, 2020 at 2:00pm Eastern Standard Time (EST).

B. QUESTIONS AND ANSWERS

Q1. As part of the project, we would like to have a clarification of Item .7 below.

2.4

TRIALS

- .1 At least three (3) weeks prior to stone production start-up, Contractor shall notify Departmental Representative of proposed source of materials.
- .2 A minimum of two (2) weeks is included in this three (3) weeks period for laboratory tests.
- .3 The Departmental Representative may require other tests during the execution of the work.
- .4 The Department Representative will be responsible for the cost of laboratory trials, otherwise trial show non-conformance.
- .5 Stone samples to be submitted at any time for laboratory testing shall be taken in the presence of the Departmental Representative or of a representative of the designated laboratory.
- .6 Contractor shall submit report of stone delivered on worksite.
- .7 Stone from the Magdalen Islands will be accepted if DFO's dolosse, imported stone and existing stone and dolosse are not sufficient to finish Work.**

A1. The 1 @ 2 mt and 300 @ 500 kg stone shall be imported to the Magdalen Islands. As quantities of stone indicated in the tender form are approximate, it is possible that an additional quantity is necessary to complete the work. If this situation should occur, the required additional armour or filter stone indicated may come from the Magdalen Islands.

Magdalen Islands stone is accepted for the other categories of stone.

Q2. In section 01 11 00 of Spec, on page 4, it is indicated that the existing slipway shall be demolished before March 31, the breakwater shall be repaired and dredging carried out before July 16 and the floating docks line moved during the month of September. However, there is no statement on when we need to build the new slipway. Could you help us please?

A2. There is no restrictions for the Slipway Work. The Slipway construction shall only be completed by September 30th, 2020.

All other terms and conditions remain the same.