

Part 1 General

1.1 REFERENCE STANDARDS

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-18, Canadian Electrical Code, Part 1, 27th Edition.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling.

Part 2 Products

2.1 JUNCTION AND PULL BOXES

- .1 Construction: welded steel enclosure.
- .2 Covers Flush Mounted: 25 mm minimum extension all around.
- .3 Covers Surface Mounted: screw-on turned edge covers.

Part 3 Execution

3.1 JUNCTION AND PULL BOXES

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Install additional pull boxes as required by CSA C22.1.
- .3 Boxes shall be accessible.

3.2 IDENTIFICATION

- .1 Equipment Identification: to Section 26 05 00 - Common Work Results for Electrical.
- .2 Identification Labels: size 2 indicating system name, voltage and phase.

END OF SECTION