



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Place Bonaventure, portail Sud-Ouest

800, rue de La Gauchetière Ouest

7^e étage, suite 7300

Montréal

Québec

H5A 1L6

FAX pour soumissions: (514) 496-3822

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada

Place Bonaventure, portail Sud-Ouest

800, rue de La Gauchetière Ouest

7^e étage, suite 7300

Montréal

Québec

H5A 1L6

Title - Sujet système d'alimentation UPS	
Solicitation No. - N° de l'invitation 31241-205593/B	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 31241-205593	Date 2020-01-17
GETS Reference No. - N° de référence de SEAG PW-SMTA-225-15592	
File No. - N° de dossier MTA-9-42221 (225)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-02-03	Time Zone Fuseau horaire Heure Normale du l'Est HNE
F.O.B. - F.A.B. Specified Herein - Précisé dans les présentes Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input checked="" type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Dubé, Stéphane	Buyer Id - Id de l'acheteur mta225
Telephone No. - N° de téléphone (514) 603-9967 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The questions and answers from the on-site visit last January 15, 2020.

Questions and answers:

Q1: Who is going to cover the cost for the replacement of the cable for the supply of the new UPS, if needed?

A1: The cost will be cover by the supplier.

Q2: What is the maximum amperage of the existing supply cable for the UPS?

A2: The maximum amperage of the existing supply cable for the UPS is 100 amps (gage #3).

Q3: What is the breaker amperage of the existing UPS?

A3: The existing breaker is 100 amps, 3 phases.

Q4: What is the period for the work execution?

A4: The work will have to be done during the normal working hours between 7:00am and 4:00pm.
A day will be schedule with the CNRC and the supplier.

Q5: What is the minimum standalone run time of the new UPS at full load (27KW) ?

A5: 9 minutes

Q6: Is there any management needed at distance for the new UPS?

A6: No management is needed at distance, only a dry contact output is needed for alarm.

Q7: What is the nature of the contract service and/or warranty?

A7: There is no service contract planned, only a 2 years warranty as specified in the specs.
The interventions under warranty will have to be done during the normal workdays between 7:00am and 4:00pm.

Q8: Where will the delivery of the new UPS be done?

A8: The delivery will be at the receiving dock at 6100 Royalmount, Montréal, QC and there is no weight limit for the trucks.

Q9: Will the new UPS be tested with a load bank?

A9: Yes for a period of 9 minutes at 27KW and 30 minutes at 10KW

Q10: Is there a speed drive for the vacuum pumps?

A10: There is no speed drive. The pumps are starting at full load and they run continuously for a several days.

Q11: Is there a plan to increase the load?

A11: No

Q12: When does the project have to be delivered?

A12: Ideally before march 31st.

N° de l'invitation - Solicitation No.

31241-205593/B

N° de réf. du client - Client Ref. No.

31241-205593

N° de la modif - Amd. No.

001

File No. - N° du dossier

MTA-9-42221

Id de l'acheteur - Buyer ID

MTA225

N° CCC / CCC No./ N° VME - FMS

Q13: Is there any restrictions having wood pallets in the laboratory.

A13 : There are no restriction.

Q14: What is the floor level of the room for the new UPS?

A14: The room is located on the ground floor at the same level as the receiving dock.

Q15: What is the width of the passage?

A15: Minimum 1.5 meter.