



# TENDER AMENDMENT

## RETURN BIDS TO:

Procurement Hub  
Fisheries and Oceans Canada  
200 Kent Street  
Ottawa, ON  
K1A 0E6

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

### Issuing Office:

Procurement Hub  
Fisheries and Oceans Canada  
200 Kent Street  
Ottawa, ON  
K1A 0E6

# MODIFICATION D'APPEL D'OFFRES

## RETOURNER LES SOUMISSIONS À :

Centre d'approvisionnement  
Pêches et Océans Canada  
200 rue Kent  
Ottawa (ON)  
K1A 0E6

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Bureau de distribution :

Centre d'approvisionnement  
Pêches et Océans Canada  
200 rue Kent  
Ottawa (ON)  
K1A 0E6

<b>Title:</b> Ile d'Entrée, Îles-de-la-Madeleine – Slipway Construction and Breakwater Repair		
<b>Solicitation No.: / N° de l'invitation :</b> FP802-190296	<b>Amendment No.: / N° de modification de l'invitation :</b> 003	<b>Date:</b> January 21, 2020
<b>Client Reference No. / No. de référence du client(e)</b> F3731-190009		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> January 29, 2020	<b>Time Zone:</b> EST (Eastern Standard Time)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b>  Nicole Levesque-Welch		
<b>Telephone No.: / N° de téléphone :</b> 343-542-5840	<b>Email Address: / Courriel :</b> <a href="mailto:nicole.levesque-welch@dfo-mpo.gc.ca">nicole.levesque-welch@dfo-mpo.gc.ca</a>	
<b>TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)</b>		
<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>		
<b>Address - Adresse</b>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		
<b>Title - Titre</b>		
<b>Signature</b>		<b>Date</b>



## AMENDMENT 003

This amendment is being raised to respond to questions that were submitted in response to solicitation FP802-190296:

### A. QUESTIONS AND ANSWERS

- Q9. On the electrical sheet, there are two lampposts to remove. These works are not described in the specifications. Can you give us details regarding the electrical work to be done?
- A9. The electrical work associated with removing the lampposts will be paid in Item 2.1 Demolition of the Slipway. The work consists of disconnecting the electrical components, remove posts and give to the Departmental Representative at another location on Work site for storage.
- Q10. The electrical sheet indicates that the two sheds near the slipway are to be removed, however these works are not indicated in the tender. Do we have to demolish these buildings? If yes, can you provide us with more details (dimensions, composition of the walls and roof of the sheds, electrical, mechanical plan, foundations, etc.)?
- A10. Work associated with moving the sheds will be paid in Item 2.1 Demolition of the Slipway. The work consists of disconnecting the electrical components inside, moving the shed and give them to the Departmental Representative at another location on Work site for storage. They are not intended to be demolished.



- Q11. On sheet 09/12 of the drawings, there is a plan view of the ramp which refers to drawing M01-09 and M-01-10. The M01-09 drawing is not included in our plans and the M01-10 does not seem to have anything to do with the plan view of the ramp. Can you provide us with these details?
- A11. Sheet 07/12, 8/12 and 9/12 of the drawings show the details of the existing hauling slip to be demolished. Drawing numbers should not be used as they are unrelated to sheet numbers of drawings.

***All other terms and conditions remain the same.***