



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Housing Renovations	
<b>Solicitation No. - N° de l'invitation</b> EZ899-202411/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2020-02-06
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-019-8723	
<b>File No. - N° de dossier</b> PWY-9-42192 (019)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-02-10</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ngan, Ken (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy019
<b>Telephone No. - N° de téléphone</b> (604) 671-0219 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> RCMP - Anahim Lake, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-202411/A  
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.  
005  
File No. - N° du dossier  
pwy-9-42192

Buyer ID - Id de l'acheteur  
pwy019  
CCC No./N° CCC - FMS No/ N° VME

---

This Solicitation Amendment 005 is raised to incorporate Addendum #1.

Please find following Addendum #1.

**All other terms and conditions remain unchanged.**

## GENERAL

The following changes / clarifications in the tender documents are effective immediately.  
This Addendum will form part of the Contract Documents.

### **1. CLARIFICATIONS**

Questions **from bidders and responses as follows:**

1. Question: Is it possible to clarify the style of wood fencing that is desired? The details (Detail 2, 3, 4, & 5 on A1.02) do not seem to be consistent. The plan view on sheet A1.02 shows a straight-line style of fence which seems more consistent with the fence style shown in Details 2 & 3; however, Details 4 & 5 show a zig-zag style of fence that sits on the surface.

Response: There are two types of fencing in this project:

Type 1: Split Rail Fencing shown in details 4/A1.02 and 5/A1.02. The location of split rail fencing is shown on A1.02 at the northwest portion of the site. Split rail fencing shown on the Site plan (straight-line style) is schematic only. Split rail fencing is to be installed (zig-zag) as per detail 4/A1.02.

Type 2: Wood Fence shown in details 4/A1.02 and 5/A1.02. The location of the wood fencing is in front (south) of the proposed residence. This is to be installed as indicated (straight-line) on the Site Plan per details 4/A1.02 and 5/A1.02.

**End of Addendum 01**