



RETURN BIDS TO:
RETOURNER LES SUBMISSION À :
Parks Canada Agency Bid Receiving Unit
220 - 4 Avenue S.E., Suite 720
Calgary, AB T2G 4X3
Bid Fax: (866) 246-6893

**REVISION 004 TO INVITATION
TO TENDER**

**RÉVISION 004 À APPEL
D'OFFRES**

The referenced document is hereby revised;
unless otherwise indicated, all other terms and
conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf
indication contraire, les modalités de l'offre
demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
National Contracting Services
220 - 4 Avenue S.E., Suite 720
Calgary, AB T2G 4X3

Title - Sujet : Day Use Areas Reconstruction Early Works – Waterton Lakes National Park	
Solicitation No. - N° de l'invitation : 5P420-19-0416/A	Date : February 6, 2020
Amendment No. - N° de modification : 004	
Client Reference No. - N° de référence du client : 2049	
GETS Reference No. N° de reference de SEAG : PW-20-00904047	
Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : February 12, 2020	Time Zone - Fuseau horaire MST
F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>	
Address Enquiries to - Adresser toutes demande de renseignements à : Jen Maheu	
Telephone No. - N° de telephone : (587) 432-8458	Fax No. -N° de télécopieur : (866) 246-6893
Email Address – Courriel : jennifer.maheu@canada.ca	
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : Waterton Lakes National Park	
TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE	
Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Amendment 004

This amendment is being raised to distribute the answers to bidder questions.

A. QUESTIONS AND ANSWERS

Q22 Concerning the roof replacement; what gauge of steel are you wanting used, is there a spec that I missed?

A22 Please refer to the specification Section 07 41 13, Article 2.1.2.

Q23 Do you have any dimensions and slopes of the roofs on the buildings?

A23 Approximate roof replacement areas:

Little Prairie - Kitchen shelter: 51 m2+/-

Lost Horse - Kitchen Shelter/Privy: 80 m2+/-

Q24 Insurance: Can I submit a letter from my insurance provider stating that I qualify for your 10million aggregate coverage and upon award of contract I will provide certificate with full coverage?

A24 The Certificate of Insurance is only required by the successful bidder after award.

Q25 Could you please clarify for the WLNP DUA Early Works that for the roof removals that it is only the wooden shingles and flashings being removed?

A25 Correct

Q26 The existing structure and wood sheathing is to remain, correct?

A26 Correct

Q27 I would like to inquire about the removal of the existing shelter Scope of Work at the Knight's Lake Day Use Area. Sheet 6 of 9 in the drawings has a photo 1 and 2 showing shelter. My question is, does the concrete slab have to be removed? This slab is at the center of the shelter and is under the chimney.

A27 Existing concrete slab to remain

Q28 Regarding the WLNP DUA Early Works I noticed that Section 07 41 13 outlines the requirement for stamped shop drawings from an engineer for the roofing. Because it appears that the existing structure is to remain, will this be a requirement?

A28 As outlined in Section 07 41 13 - 1.7.3.1 to .3:

Yes, shop drawings shall bear the seal and stamp of a Professional Engineer experienced in the design of this work and license in the province of Alberta. For information to be addressed in the shop drawing refer to section 1.7.3.2.1-.11 and 1.7.3.3.

Q29 At the Bison jump Day Use Area, do the burnt steel remnants remain on site?

Please see Photo 3, page 2 of 9 in the Plans.

A29 The burnt remains are being taken out as part of separate project

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED