Public Services and	Regina, Saskatchewan	Addendum No. 6
Procurement Canada	Tunnel Revitalization	Page 1
	Solicitation # M5000-202291/A	
		February 7, 2020

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1. General

- 1-1 This Addendum is issued prior to Tender closing to provide for certain revisions as noted herein.
- 1-2 All such revisions will become part of the Work and the effects shall be included in the Bid Price.
- 1-3 All work shall be performed in accordance with the Contract Documents.

2. Questions & Answers

Question: After consultation with several key subcontractors, and our own review, we would like to bring it to attention that there are some major concerns from the standpoint of relocation of existing utilities within this project. With the information provided, including all addenda, there is a significant lack of detail to allow for relocation of services should they be encountered. We are strongly in favour of a cash allowance being designated into the tender to both reduce risk and ensure the client receives the best pricing possible.

Answer: Contractor shall hydrovac for all known utilities as per drawings in the areas of excavation, which includes the tunnels (new construction and demolition), water and telecommunications. Relocation of conflicting utilities will be determined by the Departmental Representative and be a change to the contract.