



Date : **February 10th, 2020**

Addendum number : **01**

Project number : **R.077243.500 – Restoration of the upstream jetty and the island land
Sainte-Anne-de-Bellevue Canal National Historic Site**

The following modifications to the tender documents come into effect immediately.

This addendum will form an integral part of the contract documentation.

DRAWINGS:

.1 07 – Electrical

.1 OE-32-117-25 – Layout plan

Please **replace** the drawing named OE-32-117-25 **by** the drawing OE-32-117-25 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Removed a 50mm diameter PVC RIGID conduit, empty;
- .2 Addition of a 75mm diameter PVC RIGID conduit, empty;
- .3 Addition of two 300mm x 300mm x 460mm junction boxes in the jetty;
- .4 The note No: 1,

The Contractor must replace the 40A-2P circuit breaker, from circuit 1-3, existing with a new 30A-2P circuit breaker.

Should read:

The Contractor must replace the 40A-2P circuit breaker, from circuit 1-3, existing with a new 20A-2P circuit breaker, in the existing EATON panelboard type PRL1A, 225Amp., 120/240V, 1 phase.

.2 OE-32-117-27 – Details - 2

Please **replace** the drawing named OE-32-117-27 **by** the drawing OE-32-117-27 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Modifications to the sections Nos: 3, 4 and 5 and to the detail of the installation of electrical conduits, according to the removal and the addition of PVC RIGID conduit.
- .2 Correction to the single line – existing lighting control panel to modify, according to the circuit breaker to replace.



.2 08 – Structural

.1 OA-32-117-04 – Projected general layout (Reconstruction)

Please **replace** the drawing named OA-32-117-04 **by** the drawing OA-32-117-04 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Addition of two junction boxes on the upstream jetty.

.2 OA-32-117-05 – Demolition & reconstruction - Sections

Please **replace** the drawing named OA-32-117-05 **by** the drawing OA-32-117-05 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Modifications to the notes regarding the addition of PVC conduits on the upstream jetty.

.3 OA-32-117-06 – Demolition & reconstruction – Sections & details

Please **replace** the drawing named OA-32-117-06 **by** the drawing OA-32-117-06 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Addition of two junction boxes on the upstream jetty.
- .2 Modifications to the notes regarding the addition of PVC conduits on the upstream jetty.

.4 OA-32-117-07 – Demolition & reconstruction – Sections & details

Please **replace** the drawing named OA-32-117-07 **by** the drawing OA-32-117-07 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Modifications to the notes regarding the addition of PVC conduits on the upstream jetty.

.5 OA-32-117-08 – Demolition & reconstruction – Sections & details

Please **replace** the drawing named OA-32-117-08 **by** the drawing OA-32-117-08 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Modifications to the notes regarding the addition of PVC conduits on the upstream jetty.



.6 OA-32-117-13 – Bumber rails – Sections & details

Please **replace** the drawing named OA-32-117-13 **by** the drawing OA-32-117-13 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Addition of two junction boxes on the upstream jetty.

.7 OA-32-117-14 – Guard rails – Sections & details

Please **replace** the drawing named OA-32-117-14 **by** the drawing OA-32-117-14 (Addendum N° 01) attached.

The modifications listed below have been made:

- .1 Addition of a junction box on the upstream jetty.

Prepared by :

Marc-Olivier Bessette, ing.