



INVITATION TO TENDER (ITT)

AMENDMENT #1

RETURN BIDS TO:

**Parks Canada Agency - Central Registry
Contracting Operations
111 Water Street East
Cornwall, Ontario, K6H 6S2
Solicitation No. 5P201-19-0169/A**

Tender to: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Comments:

Vendor/Firm Name and Address:

Issuing Office

**Parks Canada Agency - Central Registry
Contracting Operations,
111 Water Street East
Cornwall, Ontario, K6H 6S2**

Title-Sujet Rehabilitation of the stone powder magazine at Fort George National Historic Site.		
Solicitation No. - No. de l'invitation 5P201-19-0169/A	Date : March 6, 2020	
GETS Reference No. - No de reference de SEAG PW-20-00908123	Client Ref. No. - No. de réf du client.	
Solicitation Closes (YY-MM-DD):		
at - à 2:00 PM	on - le 2020-03-17	Time Zone - Fuseau horaire : EDT - HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: Adresser toute demande de renseignements à : Sheldon Lalonde (sheldon.lalonde@canada.ca)		
Telephone No. - No de téléphone (613) 938-5948	Fax No. - No de FAX: (877) 558-2349	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction :		
See Herein - Voir aux présentes		
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur		
Titale - Titre		
Telephone No. - N° de téléphone: _____		
Facsimile No. - N° de télécopieur: _____		
Signature	Date	

AMENDMENT #1

March 06, 2020

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;

1) Questions and Answers #1;

Q1: Do we have access to the interior of the building?

A1: Interior access will be required in order to complete the metal work outlined in the documents, contractor to arrange access with Parks Canada when required.

Q2: How far down does the restoration work on the walls and buttresses go?

A2: Work is limited to above grade, there will be no work requiring excavation.

Q3: Where can we have a layup area for material storage and equipment?

A3: Layup areas will be determined after award of contract.

Q4: Are the doors and shutters to be replaced or repaired.

A4: Work on doors and windows are outline in the drawings and specifications, they are required to be cleaned and repaired where needed.

Q5: Are we to leave the copper roofing material on site?

A5: Yes, the old copper material is to stay onsite and remain property of Parks Canada.

Q6: Will we be required to allow public access to the building during construction?

A6: No, the building will be closed to the public for safety during construction, although surrounding areas will be required to allow public to walk around and access the tunnel.

Q7: Are we able to use a bagged mortar mix in lieu of site mixed? Using site mix will delay work for approximately 28 days to allow for testing.

A7: Bagged mortar mix will be considered after contract award.

Q8: Who attended the site visit?

A8: See attached.

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED.