





- REFERRAL NOTES:
- 1 CONDUIT AND CABLING BACK TO UTILITY TRANSFORMER SIZED PER SINGLE LINE DIAGRAM.
 - 2 SUITE FEEDER CONDUCTORS SIZED PER SINGLE LINE DIAGRAM.
 - 3 SUITE TELECOM CONDUITS. 1-27mm C/W CATV CABLE FOR SHAW AND 1-27mm C/W CAT5E CABLE FOR TELUS TO EACH SUITE. STUB CONDUITS INTO SUITE TELECOM PANELS, REFER TO PLAN DRAWINGS FOR LOCATIONS.
 - 4 SHAW AND TELUS SERVICE CONDUITS. PROVIDE 1-103mm CONDUIT FOR SHAW AND 1-53mm CONDUIT FOR TELUS BACK TO TELECOM UTILITY PEDESTAL REFER TO SITE PLAN DRAWINGS FOR PEDESTAL LOCATIONS.
 - 5 SHAW AND TELUS UTILITY SERVICE BOXES. COORDINATE SPECIFIC INFORMATION WITH RESPECTIVE UTILITY REQUIREMENTS.



- UNDERGROUND INSTALLATION NOTES:
- uA. ALL CABLING INSTALLED UNDERGROUND WILL FOLLOW THE RULES AND BE SUBJECT THE DE-RATING AS DESCRIBED IN CEC 2015.
 - uB. FOR THIS INSTALLATION THE UNDERGROUND CABLE BETWEEN THE UTILITY CONNECTION AND THE SERVICE ENTRANCE METER STACK (MS-01) SHALL BE INSTALLED IN ACCORDANCE WITH DIAGRAM D11 OF CEC 2015.
 - uC. THE SERVICE ENTRANCE CABLE WHEN INSTALLED TO THE CONFIGURATION DIAGRAM D11 OF CEC 2015 MEETS REQUIREMENTS OF THE CODE OUTLINED IN TABLE D11B. AS SUCH NO IEEE 835 CALCULATION IS REQUIRED.
 - uD. IF THE ELECTRICAL CONTRACTOR WISHES TO RECONFIGURE THE INSTALLATION OF THE SERVICE ENTRANCE CABLE OR CHANGE CABLE TYPE OR SIZE THEN THE CONTRACTOR MUST OBTAIN AN IEEE 835 CALCULATION AND SUBMIT IT FOR REVIEW PRIOR TO INSTALLING CABLE.

- GENERAL NOTES:
- A) 'X-KAIC SYM.' DENOTES CALCULATED SHORT CIRCUIT CURRENT AVAILABILITY.
 - B) SHORT CIRCUIT LEVELS BELOW 10KAIC SYM. ARE NOT SHOWN.
 - C) IC LEVELS SHOWN REPRESENT MINIMUM REQUIRED INTERRUPTING CAPACITY. EQUIPMENT CAN HAVE IC RATINGS HIGHER THAN LEVELS INDICATED.
 - D) ALL CONNECTIONS TO ROTATING MECHANICAL EQUIPMENT SHALL BE COPPER CONDUCTORS.
 - E) SERIES RATING OF EQUIPMENT SHALL ONLY BE PERMITTED WHERE CALCULATED FAULT CURRENT EXCEEDS 22kA.
 - F) METER STACKS FEEDING RESIDENTIAL SUITES DO NOT SHOW ALL PANELS CONNECTED TO THEM. REFER TO SUITE PANEL FEEDER SCHEDULES BELOW FOR CABLE, BREAKER SIZE AND PANELS FED FROM EACH METER STACK.
 - G) IN SUITE PANELS SHALL BE AS FOLLOWS:
60A FEEDER BREAKER - 60A PANEL
90A FEEDER BREAKER - 100A PANEL
100A FEEDER BREAKER - 100A PANEL.



REPUBLIC ARCHITECTURE INC

385 St. Mary Avenue
Winnipeg, MB R3C 0N1

T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca



NORR

2300, 411 1st Street SE,
Calgary, Alberta, Canada T2G 4Y5
norr.com

NORR ARCHITECTS ENGINEERS PLANNERS
A Partnership of Limited Companies
Poon McKenzie Architects (Alberta) Inc. Poon McKenzie Holdings Inc.
NORR is a trademark owned by Poon McKenzie Group Inc. and is used under license.

Victor Smith, Architect, AAA, B.Arch, MABC
Bruce McKenzie, Architect, AAA, B.Arch, MABC
A. Shro Siddiqui, Architect, AAA, B.Arch, MABC
Amin Toolea, P.Eng., APEGA
Chris Pal, P.Eng., APEGA

Revised	Description	Date
5	ISSUED FOR CONSTRUCTION	2020-03-06
4	ISSUED FOR ADDENDUM E01	2019-11-19
3	66% CLIENT REVIEW	2019-08-29
2	66% CLIENT REVIEW	2019-05-09
1	33% CLIENT REVIEW	2019-03-14

Client: PSPC

10025 JASPER AVE
EDMONTON, AB, T5J 1S6
PH. 780-919-9445

Project Name: JASPER STAFF HOUSING CONSTRUCTION

DUPLEX


720 PATRICIA STREET
JASPER, AB, T0E 1E0

Designed by: R.ALLEN
Drawn by: F.HAK
Approved by: D.HIDER
Project Manager / Administrateur de Projets: ROB HAFER


Brawing Title: ELECTRICAL DETAILS & RISERS

R.100429.001
E3.0
OF
5


1 METER STACK DETAILS SCALE: N.T.S.




2 SINGLE LINE DIAGRAM SCALE: N.T.S.



5 GANGED SWITCHES DETAIL SCALE: 1 : 50



4 BUILDING TOWNHOME GROUNDING SCALE: N.T.S.



3 TYPICAL SUITE PANEL ELEVATION SCALE: N.T.S.

