

385 St. Mary Avenue
Winnipeg, MB R3C 0N1

T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca



NORR

2300, 411 1st Street SE,
Calgary, Alberta, Canada T2G 4Y5
norr.com

NORR ARCHITECTS ENGINEERS PLANNERS
A Partnership of Limited Companies
Poon McKenzie Architects (Alberta) Inc., Poon McKenzie Holdings Inc.,
NORR is a trademark owned by Ingenium Group Inc. and is used under license.

Victor Smith, Architect, AAA, B.Arch, MAIBC
Bruce McKenzie, Architect, AAA, B.Arch, MAIBC
A. Silvio Baldassarra, Architect, AAA, B.Arch, MAIBC
Adrian Todella, P.Eng., APEGA
Chris Pal, P.Eng., APEGA

5	ISSUED FOR CONSTRUCTION 2	2020/03/06
4	ISSUED FOR CONSTRUCTION	2019/10/29
3	ISSUED FOR 90% REVIEW	2019/08/29
2	ISSUED FOR 66% REVIEW	2019/05/09
1	ISSUED FOR 33% REVIEW	2019/03/14
Revision	Description	Date
Client		client

PSPC

10025 JASPER AVE
EDMONTON, ALBERTA, T5J 1S6
PH. 780-919-9445

Project title	Project
JASPER STAFF HOUSING CONSTRUCTION	

5 PLEX

902 PATRICIA STREET
JASPER, AB, T0E 1E0

Designed by	Conçu par
H. HUANG	

Drawn by	Dessiné par
D. GREGOIRE	

Approved by	Approuvé par
M. ABUALQUMSSAN	

PWGSC Project Manager Administrateur de Projets TPSGC
ROB HAFFER

Drawing Title	Titre du dessin
---------------	-----------------

LOWER LEVEL AND MAIN FLOOR HEATING PLAN

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
---------------------------	---------------------------	--------------

R.100429.001	M4.1 OF	5
--------------	------------	---



KEYNOTES:

1. 203 HWS & HWR PIPING CONNECT TO CABINET UNIT HEATER AT ENTRANCE. CONTROLLED BY THERMOSTAT.
2. MOUNT THERMOSTAT @ 1500 MM A.F.F. TYP. PROVIDE LOCKABLE COVER FOR THERMOSTATS IN PUBLIC AREA.
3. CONTRAL VALVE AND ISOLATION VALVE.
4. TYPE B HEAT BASEBOARD INSTALLED BELOW CEILING.
5. STACK MOUNTING P-1 & P-2.
6. CIRCUIT BALANCING VALVE AT 0.15L/S.
7. CIRCUIT BALANCING VALVE AT 0.15L/S.
8. CIRCUIT BALANCING VALVE AT 0.30L/S.
9. CIRCUIT BALANCING VALVE AT 0.30L/S.
10. HWS UP FROM JOIST TO BASEBOARD CABINET.
11. HWR DOWN RUN IN THE FLOOR JOIST BELOW.
12. THERMOSTATS TO BE CONNECTED TO CONTROL AND DISTRIBUTION PANEL IN THE MECHANICAL ROOM. PROVIDE LOCKABLE COVER FOR THERMOSTATS IN PUBLIC AREA.

GENERAL NOTES:

- A. ALL HWS AND HWR SHALL BE 20Ø OR OTHERWISE NOTED.
B. PROVIDE RADIATION CABINET FOR HEATING PIPING AS INDICATED.
C. AIR TRAP TO BE PROVIDED AS REQUIRED.
D. CONTRACTOR TO COORDINATE WITH JOIST MANUFACTURER REGARDING THE LOCATION OF PIPE PENETRATION THROUGH THE JOIST PRIOR TO CONSTRUCTION.

