

APEGA PERMIT TO PRACTICE NO.
11944
06/03/2020

NORR

2300, 411 1st Street SE,
Calgary, Alberta, Canada T2G 4Y5
norr.com

NORR ARCHITECTS ENGINEERS PLANNERS
A Partnership of Limited Companies

Yvonne Smith, Architect, AAA, B.Arch, MABC
Bruce McKenzie, Architect, AAA, B.Arch, MABC
A. Shiro Siddhanta, Architect, AAA, B.Arch, MABC
Anirban Tootia, P.Eng., APEGA
Chris Pal, P.Eng., APEGA

Revision	Description	Date
5	ISSUED FOR CONSTRUCTION 2	2020/03/06
4	ISSUED FOR CONSTRUCTION	2019/10/29
3	ISSUED FOR 90% REVIEW	2019/08/29
2	ISSUED FOR 60% REVIEW	2019/05/09
1	ISSUED FOR 30% REVIEW	2019/03/14

Revision Client Description Date

PSPC

10025 JASPER AVE
EDMONTON, ALBERTA, T5J 1S6
PH. 780-919-9445

Project Title Project
JASPER STAFF HOUSING CONSTRUCTION

5 PLEX

902 PATRICIA STREET
JASPER, AB, T0E 1E0

Designed by Conçu par
H. HUANG

Drawn by Dessiné par
D. GREGOIRE


Approved by Approuvé par
M. ABUALQUMSSAN

Project Manager / Administrateur de Projets / Project Manager
ROB HAFER


Drawing Title Titre du dessin
LOWER LEVEL AND MAIN FLOOR
VENTILATION PLAN

Project no./No. du projet Drawing no./No. du dessin Revision no.
R.100429.001 M3.1 5


OF



1 LOWER LEVEL VENTILATION PLAN
SCALE: 1 : 50



3 ERV-1 SECTION
SCALE: 1 : 50



2 MAIN LEVEL VENTILATION PLAN
SCALE: 1 : 50

KEYNOTES:

- 300x150 RETURN AIR DUCT WITH 25MM THICKNESS ACOUSTIC INSULATION FROM BELOW.
- 300x150 SUPPLY AIR DUCT WITH 25MM THICKNESS ACOUSTIC INSULATION FROM BELOW.
- 250x150 RETURN AIR DUCT WITH 25MM THICKNESS ACOUSTIC.
- 250x150 SUPPLY AIR DUCT WITH 25MM THICKNESS ACOUSTIC.
- 125Ø FIRE DAMPER. COORDINATE EXACT LOCATION OF ACCESS DOOR ON SITE.
- 300x200 FIRE DAMPER. COORDINATE EXACT LOCATION OF ACCESS DOOR ON SITE.
- 200x200 FIRE DAMPER. COORDINATE EXACT LOCATION OF ACCESS DOOR ON SITE.
- 2 100Ø DRYER EXHAUST THROUGH WALL WITH EXTERNAL INSULATION.
- 75Ø COMBUSTION AIR DUCT AND VENT FROM/TO THE BOILER/DWH TO/FROM EXTERIOR WALL AS PER MANUFACTURER'S RECOMMENDATIONS.
- 150Ø KITCHEN EXHAUST DUCTWORK THROUGH WALL WITH RAIN CAP AND BACKDRAFT DAMPER. EXTERNALLY INSULATE KITCHEN EXHAUST.
- 200Ø MAKE UP AIR DUCT WITH EXTERNAL INSULATION DOWN TO FLOOR WITH COLD AIR TRAP.
- REVERSE ACTING THERMOSTAT CONNECTED WITH EF-2 AND MAKE-UP AIR MOTORIZED DAMPER. WHEN MECHANICAL ROOM TEMPERATURE RISE TO SET-POINT EF-2 RUNS AND MAKE-UP AIR MOTORIZED DAMPER OPENS. REFER TO M1.2 DETAIL 10.
- HRV CONTROLLER ON WALL. PHC-1 TO BE CONTROLLED BY DUCT MOUNTED DISCHARGE AIR TEMP. SENSOR.
- EF-1 IS LOCATED IN RATED CEILING. EXHAUST PIPE RUNS THROUGH JOIST SPACE TO EXTERIOR WALL. E/A DUCT WITH EXTERNAL INSULATION AND BACKDRAFT DAMPER.
- PROVIDE 100mm PVC VENT PIPE AND CAPPED FOR RADON EXTRACTION SYSTEM. REFER TO DRAWING M2.1. CONTRACTOR TO ALLOW FOR RADON VENT PIPE TO DISCHARGE THROUGH EXTERIOR WALL, INCLUDING ROUGH-IN PIPING FOR RADON EXHAUST FAN RD-1 TO BE INSTALLED IN MECHANICAL ROOM, INCLUDING ALLOWANCE FOR PIPING INSULATION TO PREVENT FREEZING.
- E/A DUCT WITH EXTERNAL INSULATION AND BACKDRAFT DAMPER.
- DUCT RUNNING BELOW JOIST