



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Canteen Relocation, Building M	
<b>Solicitation No. - N° de l'invitation</b> EZ899-202574/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2020-03-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-028-8745	
<b>File No. - N° de dossier</b> PWY-9-42221 (028)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-03-19</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lam (PWY), Tian	<b>Buyer Id - Id de l'acheteur</b> pwy028
<b>Telephone No. - N° de téléphone</b> (604) 363-7968 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> CSC - Building M, Mission Institution - Mission, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-202574/A

Amd. No. - N° de la modif.  
005

Buyer ID - Id de l'acheteur  
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

---

The Solicitation Amendment 005 is raised to issue Addendum 003.

Please see Addendum 003 herein.

All other terms and conditions remain unchanged.

Location: 8751 Stave Lake Street, Mission BC  
Building: Mission Medium Institution, Building M  
Canteen Relocation

---

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

**1. Question and Answers:**

- Q1. Is there a list of approved contractors for the camera system at mission?  
A1. The following companies have the certification for CSC security systems:
- Houle Electric
  - Johnson Controls Inc.
  - Paladin Security Systems
- Q2. Specs state 16 gauge sheet metal for wall construction, is that expanded steel mesh?  
A2. Expanded metal mesh
- Q3. I notice that there is no wall insulation, please confirm?  
A3. Wall assembly per tender documents.

**End of Addendum #3**

---