



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
Canada Place, 10th Floor  
9700 Jasper Avenue  
Edmonton  
Alberta  
T5J 4C3  
Bid Fax: (780) 497-3510

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Public Works and Government Services Canada/Travaux  
publics et Services gouvernementaux Canada  
Harry Hays Building (HHB)  
Room 759, 220-4th Avenue SE  
Calgary  
Alberta  
T2G 4X3

<b>Title - Sujet</b> UPS and Battery Cabinets	
<b>Solicitation No. - N° de l'invitation</b> 6D063-193681/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> 6D063-193681	<b>Date</b> 2020-04-16
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$CAL-129-7032	
<b>File No. - N° de dossier</b> CAL-9-42103 (147)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-04-21</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Law, Brian	<b>Buyer Id - Id de l'acheteur</b> cal147
<b>Telephone No. - N° de téléphone</b> (403) 478-5462 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Contract No. - N° du contrat  
6D063-193681/A  
Client Ref. No. - N° de réf. du client  
6D063-193681

Amd. No. - N° de la modif.  
004  
File No. - N° du dossier  
CAL-9-42103

Buyer ID - Id de l'acheteur  
Cal147  
CCC No./N° CCC - FMS No./N° VME

---

**This amendment 004 is being raised to amend solicitation 6D063-193681/A as follows:**

**Question and Answer:**

**Question:** Regarding the LiFePo4 battery question in Amendment 3, we have not seen any LFP manufacturer passing the UL9540A fire test yet – can you confirm if the LiFePo4 battery is approved for this project?

**Answer:** Yes, providing that the proposed unit is CSA approved as per the Canadian Electrical Code. Please see the amended section below.

**Refer to RFP page 11 of 20, section entitled 6.11 – SACC Manual Clauses**

**Insert:** B1501C – Electrical Equipment

All electrical equipment supplied under the Contract must be certified or approved for use in accordance with the Canadian Electrical Code, Part 1, before delivery, by a certification organization accredited by the Standards Council of Canada.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME AND ARE IN FULL EFFECT**