

Wharf Reconstruction - George Island, MB (F2470-200002)

Addendum forms part of the Contract Documents and modifies the Bidding Documents dated February 2020, with amendments and additions noted below. Where inconsistent with the drawings and specification, this Addendum shall govern. The same conditions of Contract and General Requirements shall apply to this Addendum as to the original drawings and specifications. Bidders are to review the entire Addendum to confirm all work affecting their Section.

Section 35 59 11
FLOAT WHARF FABRICATION
Page 33

Part 2 Products

2.1 MATERIALS, .1

.16 Flotation units:

Delete:

- .1 Flotation units shall be of size 219 mm x 2438 mm x 610 mm with a minimum buoyancy of 1623 kg each.

Insert:

- .1 Flotation units shall be of size 1219 mm x 2438 mm x 610 mm with a minimum buoyancy of 1623 kg each.