



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Environmental Logistics Depot	
Solicitation No. - N° de l'invitation F1700-195560/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F1700-195560	Date 2020-05-13
GETS Reference No. - N° de référence de SEAG PW-\$PWY-020-8768	
File No. - N° de dossier PWY-9-42228 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-06-05	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ly, Ronny(PWY)	Buyer Id - Id de l'acheteur pwy020
Telephone No. - N° de téléphone (604) 318-5750 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – Port Hardy, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-195560/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwy020

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

This Amendment 003 is raised to issue Addendum #1.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

ADDENDUM #1

Date: May 13, 2020

PACIFIC REGION
PORT HARDY LOGISTICS DEPOT
PORT HARDY, B.C.
Project No: 8H500

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

1.0 QUESTIONS

- Q.1 As per spec "f1700-195560_specifications (1).pdf", Section 05 50 00, Page 4, Item 2.3.5 (page 156 of document) it states "All steel (except piles and sheet piles), anchor bolts and fasteners for abutment, float and mooring piles shall be hot dip galvanized, unless otherwise noted." Is this a firm requirement for all structural steel?
- A.1 Structural steel used in the float and ramp shall be hot dip galvanized. Structural steel in the building shall be primed and painted.
- Q.2 Please confirm if the DP and BP are to be applied for and paid for by the Owner or the General Contractor.
- A.2 No development permit or building permit will be required. General contractor shall be responsible for any other required permits, such as an electrical permit.
- Q.3 Please confirm if the materials testing is going to be paid for by the Owner or General Contractor.
- A.3 Any required materials testing shall be paid for by the general contractor.
- Q.4 Please confirm if the temp utilities during construction are to be paid for by the Owner or General Contractor.
- A.4 The General contractor shall pay for on-site electrical infrastructure. Owner shall pay for electrical usage.
- Q.5 Please confirm if temp power is available on site and that the General Contractor can use this. If so voltage / KW/ amps /3 phase ? please provide details
- A.5 General contractor may use the on-site power. We do not have details regarding the existing electrical service available.
- Q.6 Please confirm if there is water supply on site for connection or is it a underground tank
- A.6 Tap water is available.
- Q.7 Confirm if there are any underground tanks on site that require removal
- A.7 All available information regarding site conditions is contained in the specification appendices.
- Q.8 Please provide drawings for the existing buildings on site and the foundation depths and type of construction below ground. ie., concrete grade beams / piles
- A.8 All available information regarding site conditions is contained in the specification appendices.
- Q.9 Is there any information available regarding the ramp dimensions and weight?
The Float dimensions and displacement?

ADDENDUM #1

Date: May 13, 2020

PACIFIC REGION
PORT HARDY LOGISTICS DEPOT
PORT HARDY, B.C.
Project No: 8H500

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

- A.9 The ramp is 40-feet long from hinge to hinge and weighs 200kN. Overall dimensions of the float are 52.440m x 17.074m x 1.718m and it displaces 915 tonnes.

END ADDENDUM #1