

The following clarifications to the tender documents are effective immediately and will form part of the contract documents:

**1. SPECIFICATIONS**

**2.1 Clarification on Junction Box, Pull Box Enclosure Type and Panelboard Enclosure Type**

In reference to Specification 26 05 31 and 26 24 16 01

For junction boxes, pull boxes and panelboards located indoors, CSA enclosure type 2 will be accepted in lieu of CSA enclosure type 12.

**END OF CLARIFICATION NO. 1**