



**RETURN BIDS TO:  
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services

**Bid Fax: 1-866-246-6893**

**Bid Email:**

[soumissionsouest-bidswest@canada.ca](mailto:soumissionsouest-bidswest@canada.ca)

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 25 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO AN  
INVITATION TO TENDER**

**RÉVISION 001 À UNE  
INVITATION À SOUMISSIONNER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités demeurent les mêmes.

**Issuing Office - Bureau de distribution :**

Parks Canada Agency  
Banff National Park

<b>Title - Sujet :</b> Johnston Canyon Campground Roofs Replacement Banff National Park, AB	
<b>Solicitation No. - N° de l'invitation :</b> 5P421-20-0007/A	<b>Date :</b> May 29, 2020
<b>Amendment No. - N° de modification :</b> 001	
<b>Client Reference No. - N° de référence du client :</b> N/A	
<b>GETS Reference No.   N° de référence de SEAG :</b> PW-20-00915065	

<b>Solicitation Closes - L'invitation prend fin :</b> <b>At - à :</b> 02 :00 PM <b>On - le :</b> June 4, 2020	<b>Time Zone - Fuseau horaire</b> Mountain Daylight Time (MDT) – Heure avancée des Rocheuses (HAR)
---------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------

<b>F.O.B. - F.A.B. :</b> <b>Plant - Usine :</b> <input type="checkbox"/> <b>Destination :</b> <input checked="" type="checkbox"/> <b>Other - Autre :</b> <input type="checkbox"/>		
<b>Address Enquiries to - Adresser toute demande de renseignements à :</b> Annie Roy		
<b>Telephone No. - N° de telephone :</b> Can be contacted by email only at this time Peut être rejointe par courriel seulement en ce moment	<b>Fax No. -N° de télécopieur :</b> 1-866-246-6893	<b>Email Address – Courriel :</b> annie.roy2@canada.ca
<b>Destination of Goods, Services, and Construction - Destination des biens, services, et construction :</b> See Herein – Voir ci-joint		

**TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE**

<b>Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :</b>	
<b>Address - Adresse :</b>	
<b>Telephone No. - N° de telephone :</b>	<b>Fax No. - N° de télécopieur :</b>
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Signature :</b>	<b>Date :</b>

Solicitation No. - N° de l'invitation :  
5P421-20-0007A

Amd. No. - N° de la modif. :  
001

Contracting Authority - Autorité contractante :  
Annie Roy

Client Ref. No. - N° de réf. du client :  
N/A

Title – Titre :  
Johnston Canyon Campground Roofs Replacement  
Banff National Park, Ab

---

## Amendment 001

This amendment is raised to:

- A. Answer questions from bidders.

### A. Questions and Answers

**Q#1:** The concrete splash pads are spec'd at 600X2400. Can blocks be laid out in a series of 6 24" x 24" blocks, or are they required to be one piece blocks?

**A#1:** No, no blocks can be laid out. They are required to be one piece concrete splash pads. The eaves trough and splash pads would only be needed on the cottage and shed.

**Q#2:** Do we need to apply wood/metal fascias to the 6 Shelter buildings? At the moment there are none on those...

**A#2:** No, we do not need fascias on the 6 shelter buildings.

**Q#3:** Could a picture be taken showing the fascia/roof edge for the theatre building?

**A#3:** There is no picture available at this time. Fascia and roof edge would only be needed on the gable ends.

**Q#4:** Is the existing plywood on the roof considered part of the roof structure to be evaluated or should it be removed with the rest of the roofing materials?

**A#4:** As per specifications, Scope of Work. See section 1.4, 1.5 and 1.6.

**Summary:** removal of roof decking on cottage, shed and the 6 shelters, leave the decking on the theatre for evaluation.

**Q#5:** Is it specified that the shelters will not need the roof underlayment, this means that the sheet metal roof will go directly over the plywood?

**A#5:** Yes, will not need roof underlayment, sheet metal roof will be applied directly to 2x4 strapping See section 1.5.4 of the Specifications, Scope of Work.

**Q#6:** What color should we paint the zinc-coated sheet steel for the roof?

**A#6:** It will be a dark green. A sample will need to be provided and approved by the project authority.

**Q#7:** What color should we paint the zinc-coated sheet steel for the flashing and trim?

**A#7:** It will be a dark green. A sample will need to be provided and approved by the project authority.

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED**