



Fisheries and Oceans Canada
ADDENDUM no.2
June 16, 2020

F5211-200106 : Supply and Install New Mechanical Ventilation System at Cowichan Hatchery

QUESTIONS AND ANSWERS

Question #1:

Is it possible to change the equipment to 600 volt and feed from the CDP panel directly? If the equipment needs to stay as 208V and the existing panels can take the additional loading, can a small sub panel be added to provide the additional breaker spaces required? If the existing panels do not have the power capacity for the additional loads, can a small stepdown transform and disconnects be added from the 600 volt CDP panel to feed the new equipment?

Answer #1:

Existing Unit Heaters and their breakers are to be removed prior to project commencing. This is outside of the project scope, and will free up the space needed in the electrical panel.

Question #2:

Mechanical drawing M1 does not indicate any acoustic duct liner. Normally we see this on the plans via a cross hatching of the ductwork where acoustic duct liner would be required as per the symbol identified on the HVAC legend (Shown on M-2). Will any acoustic duct liner be required as per HVAC Note 5?

Answer # 2:

Acoustic lining will not be required.

Question #3:

The scheduled/specified HRV has a delivery ETA of 8 weeks minimum. With the completion date set at September 4, 2020 there is not enough time to meet that schedule as shop drawings for the HRV need to be requested, submitted, reviewed and approved prior to ordering. Furthermore, as this is specialized unit, there are no expedited or quick build options available. Can the completion date be changed to accommodate the long lead time required for ordering HRV-1?

Answer #3:

The Project Completion date will be adjusted as necessary to accommodate equipment delivery times.

Question #4:

What is required for APPENDIX 1 – INTEGRITY REGIME VERIFICATION?

Answer #4:

This is not always applicable. Please read and review section SI11 for more information



INSERT:

**ANNEX "E" PERSONNEL IDENTIFICATION FORM (PIF)
DEPARTMENT OF FISHERIES AND OCEANS CANADA**

Contract / file number: #F5211-200106

PROJECT TITLE: Supply and Install New Mechanical Ventilation System at Cowichan Hatchery

Company Name:	
Address:	
Telephone number:	
Fax number:	
PWGSC file or Certificate #:	

Professional Services (Add second page if more space needed, please print clearly)

Resource Person(s) working on this project	Date of birth YYY/MM/DD	PWGSC file or certificate #	Security Level	Meet	Does not Meet	Comments

Contractor's Authorized Signatory (Bidder) : _____

Date: _____

(For Official Use)

Company Clearance	Required	Security Level	Meet / Does not Meet / Comments (Official Use Only)
Designated Organization Screening			
Facility Security Clearance			
Document Safeguarding Capability			

**For Use at Fisheries and Oceans Canada
Authorization of Contracting Security Authority**

- I approve
- I do not approve based on:

Contracting Security Authority: _____

Date: _____