

**1.1 ADDENDUM**

- .1 This addendum shall be known as:

Addendum #02  
NWAF L16 Roof Replacement

**1.2 PRECEDENCE**

- .1 This amendment to the bid documents is effective immediately.
- .2 This Addendum shall form an integral part of the original bid documents and is to be read in conjunction therewith.
- .3 This Addendum shall take precedence over previously issued bid documents with which it may prove to be at variance.

**1.3 GENERAL**

- .1 The Amended and Restated Agreement: NAFC L16 Roof Replacement and General Conditions shall govern all phases of the work covered by this Addendum.
- .2 Acknowledge receipt of this addendum in the Tender Form.

**1.4 PURPOSE**

- .1 The purpose of this Addendum is to inform bidders of the changes and additions to be added to the bid documents.

**1.5 Contractor Questions:**

- .1 Can "picture framing" (we use all cold applied membranes at fire sensitive areas like parapets, curbs etc., and one meter out onto field) be used at all detail and penetration areas to mitigate the risk of fire?

Answer: Picture framing is acceptable as long as it is compliant with the specific roofing manufacturers installation instructions. Flame is not to come in contact with any flammable materials.

**END OF ADDENDUM #02**