



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

Title - Sujet NCR QUEBEC – GC Workplace Fit-up	
Solicitation No. - N° de l'invitation EP731-203113/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client 20203113	Date 2020-06-25
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-347-78744	
File No. - N° de dossier fg347.EP731-203113	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-06-30	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Boujenoui, Nabil	Buyer Id - Id de l'acheteur fg347
Telephone No. - N° de téléphone (613) 295-9356 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.

Amendment 008 is issued for the following:

- (1) Respond to Bidder Questions

(1) Bidder Questions and Answers

No.	QUESTION	ANSWER
117	Is it possible to have the specs for the floor monuments? No information is presented in the electrical specifications which makes the submission of this product impossible.	Bid as per plans and specs – drawings E5, note 3
118	In amendment no 2, this question was answered by stating to refer to addenda no 1. The only change to this note is that not all the floor is to be patched, but only severely damaged areas. How are we to determine this quantity without seeing the floor, which is currently covered in carpet? I insist that you provide us with a cash allowance or a number (5,10,20% of floor area) like the ceiling grid. Otherwise I will have to assume that the floor is in good condition and we will have to address this one the carpet is removed.	Bid as per plan and specs - Drawing ID-01, General Note #19, and addendum 002.
119	Giving some thought about detail 2/08 (ID-08-SKI) in Addenda no 5 (Amendment no7), the G.C. is to only provide blocking for the adult change table. From experience, if the wall is not a solid concrete block wall, adult change tables can only be supported using HSS' bolted from slab to slab spanning the width of the change table. Simply asking for backing is insufficient in this case. Please revise this detail to at least suggest an engineered drawing and structure adequate to support this. Otherwise I will only allow for a piece of plywood rather than an engineered structure.	Bid as per plan and specs, Addendum 005

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME