

### Questions and Answers:

**Q5) In regards to Item 2 in the Unit Price Table: Would PWGSC consider changing the unit of measurement to tonne instead of cubic meter? The contractors costs will be calculated in tonnes for both the transportation and disposal aspect of this line item, so pricing this per cubic meter would force us to guess at the in-place specific gravity of the contaminated soil.**

A: The unit of measurement will remain as cubic metres, and payment will be completed for the volume removed based on the difference between the pre-excavation and completed excavation surveys.

**Q6) If item 2 unit remains at cubic meter can PWGSC provide the in-place specific gravity of the contaminated soil so that we can correctly calculate the tonnage?**

A: This is the contractor's responsibility and no separate payment will be made for claims associated with specific gravity different than what assumed.

**Q7) Is there a survey layout of the site that we can reference to ensure we only excavate to the requirements of each phase (ex, 100mm above top liner, etc.)?**

A: There is no survey data available.