

Part 1 General

1.1 SECTION INCLUDES

- .1 Requirements and procedures for identification of Building Energy Monitoring and Control System (EMCS) devices such as: sensors; wiring; tubing; conduit; and equipment. This section covers requirements for nameplate materials, colours and lettering sizes.

1.2 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 25 05 01 - EMCS: General Requirements.
- .3 Section 23 05 53 01 – Mechanical Identification.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International):
 - .1 CSA C22.1 - The Canadian Electrical Code, 2012, Safety Standard for Electrical Installations.

1.4 SYSTEM DESCRIPTION

- .1 Language Operating Requirements: provide identification for control items in English.

1.5 SUBMITTALS

- .1 Submittals in accordance with:
 - .1 Division 01 – General Requirements.
 - .2 Section 21 05 01 – Common Work Results for Mechanical.
- .2 Submit samples to Owner’s Representative for pre-approval. Include samples of nameplates, identification tags and list of proposed wording.

Part 2 Products

2.1 WARNING LABELS

- .1 Permanent warning labels shall be affixed to all equipment which can be automatically started by the EMCS system.
 - .1 Labels shall use white lettering (12-point type or larger) on a red background.
 - .2 Warning labels shall read as follows:

C A U T I O N

This equipment is operating under automatic control and may start or stop at any time without warning. Switch disconnect to “Off” position before servicing.

- .2 Permanent warning labels shall be affixed to all motor starters and all control panels which are connected to multiple power sources utilizing separate disconnects.
 - .1 Labels shall use white lettering (12-point type or larger) on a red background.

- .2 Warning labels shall read as follows:

C A U T I O N

This equipment is fed from more than one power source with separate disconnects. Disconnect all power sources before servicing.

2.2 IDENTIFICATION OF HARDWARE AND WIRING

- .1 All wiring and cabling, including that within factory-fabricated panels, shall be labelled at each end within 5 cm of termination with the information provided as sample. See Appendix I – Object Tagging.

Field Equipment Identification: To be as per laminated sample.

- .1 To include the following:
- .1 Scale/set-up range.
 - .2 Panel (controller) address.
 - .3 Point address.
 - .4 Device Part #/Manufacturer.
 - .5 To be orange background.
- .2 All pneumatic tubing shall be labelled at each end within 5 cm of termination with a descriptive identifier.
- .3 Permanently label or code each point/object of field terminal strips to show the instrument or item served.
- .4 Identify control panels with minimum 1 cm letters on laminated plastic nameplates.
- .5 Identify all other control components with permanent labels. All plug-in components shall be labelled such that removal of the component does not remove the label.
- .6 Identify room sensors relating to terminal box or valves with nameplates.
- .7 Identifiers shall match record documents.
- .8 Conduit:
- .1 Colour code EMCS conduit. Confirm colour coding with Owner’s Representative during project start-up meeting.
 - .2 Pre-paint box covers and conduit fittings as per Owner’s Standards.

Part 3 Execution

3.1 NAMEPLATES AND LABELS

- .1 Ensure that manufacturer's nameplates, CSA labels and identification nameplates are visible and legible at all times.

3.2 EXISTING PANELS

- .1 Correct existing nameplates and legends to reflect changes made during Work.

END OF SECTION