

Part 1 General

1.1 GENERAL REQUIREMENTS

- .1 The Contractor shall be responsible to carry out all the Work set out or referred to in this Section 21 07 16.

1.2 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

1.3 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE):
 - .1 ANSI/ASHRAE/IESNA 90.1-01-SI, Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2 American Society for Testing and Materials (ASTM International):
 - .1 ASTM B209M-01, Specification for Aluminum and Aluminum Alloy Sheet and Plate.
 - .2 ASTM C335-95, Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C411-97, Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C449/C449M-00, Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C533-95 (2001), Specification for Calcium Silicate Block and Pipe Thermal Insulation.
 - .6 ASTM C547-00, Specification for Mineral Fiber Pipe Insulation.
 - .7 ASTM C553-00, Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications.
 - .8 ASTM C612-00a, Specification for Mineral Fiber Block and Board Thermal Insulation.
 - .9 ASTM C795-92 (1998) e1, Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
 - .10 ASTM C921-89 (R1996), Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.
- .3 Canadian General Standards Board (CGSB):
 - .1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .2 CGSB 51-GP-53M-95, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts.
- .4 Thermal Insulation Association of Canada (TIAC):
 - .1 National Insulation Standards 1992 (R1999).

- .5 Underwriters Laboratories of Canada (ULC):
 - .1 CAN/ULC-S102-M88 (R2000), Surface Burning Characteristics of Building Materials and Assemblies.

1.4 PRODUCT DATA

- .1 Submit product data in accordance with Division 01 – General Requirements.

1.5 SAMPLES

- .1 Submit samples in accordance with Division 01 – General Requirements.
- .2 Submit for approval by Engineer: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix typewritten label beneath sample indicating service.

1.6 MANUFACTURER'S INSTRUCTIONS

- .1 Submit manufacturer's installation instructions in accordance with Division 01 – General Requirements.
- .2 Installation instructions to include procedures to be used, installation standards to be achieved.

1.7 QUALIFICATIONS

- .1 Subcontractor responsible for installation to be specialist in performing work of this section, and have at least 3 years successful experience in this size and type of project, member of TIAC.

1.8 DELIVERY, STORAGE AND HANDLING

- .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Protect from weather and construction traffic.
- .3 Protect against damage from any source.
- .4 Store at temperatures and conditions recommended by manufacturer.

1.9 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Division 01 – General Requirements.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to approved metal recycling facility.

- .5 Divert unused adhesive materials from landfill to official approved hazardous material collections site approved.
- .6 Do not dispose of unused adhesive materials into sewer systems, into lakes, streams, onto ground or in other locations where it will pose health or environmental hazard.

Part 2 Products

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102:
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre: includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24°C mean temperature when tested in accordance with ASTM C335.
- .3 TIAC Code A-1: Rigid moulded mineral fibre without factory applied vapour retarder jacket:
 - .1 Mineral fibre: ASTM C547.
 - .2 Maximum "k" factor: ASTM C547.
- .4 TIAC Code A-3: Rigid moulded mineral fibre with factory applied vapour retarder jacket:
 - .1 Mineral fibre: ASTM C547.
 - .2 Jacket: to CGSB 1-GP-52Ma.
 - .3 Maximum "k" factor: ASTM C547.
- .5 TIAC Code C-1: Rigid mineral fibre board, un-faced:
 - .1 Mineral fibre: ASTM C612.
 - .2 Maximum "k" factor: ASTM C612.
- .6 TIAC Code C-4: Rigid mineral fibre board faced with factory applied vapour retarder jacket:
 - .1 Mineral fibre: ASTM C612.
 - .2 Jacket: to CGSB51-GP-52Ma.
 - .3 Maximum "k" factor: ASTM C612.
- .7 TIAC Code C-2: Mineral fibre blanket unfaced or faced with factory applied vapour retarder jacket (as scheduled in PART 3 of this section):
 - .1 Mineral fibre: ASTM C553.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: ASTM C553.

- .8 TIAC Code A.6: Flexible unicellular tubular elastomer:
 - .1 Insulation: with vapour retarder jacket.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor.
 - .4 Certified by manufacturer free of potential stress corrosion cracking corrodants.
- .9 TIAC Code A-2: Rigid moulded calcium silicate in sections and blocks, and with special shapes to suit project requirements:
 - .1 Insulation: ASTM C533.
 - .2 Maximum "k" factor: ASTM C533.
 - .3 Design to permit periodic removal and re-installation.

2.3 CEMENT

- .1 Thermal insulating and finish:
 - .1 To: ASTM C449/C449M.
 - .2 Hydraulic setting or Air drying on mineral wool, to ASTM C449.

2.4 JACKETS

- .1 Polyvinyl Chloride (PVC):
 - .1 One-piece moulded type and sheet to CGSB 51-GP-53M with pre-formed shapes as required.
 - .2 Colours: to match adjacent finish paint selected by Architect.
 - .3 Minimum service temperatures: -20°C.
 - .4 Maximum service temperature: 65°C.
 - .5 Moisture vapour transmission: 0.02 perm.
 - .6 Thickness: 0.5 mm.
 - .7 Fastenings:
 - .1 Use solvent weld adhesive compatible with insulation to seal laps and joints.
 - .2 Tacks.
 - .3 Pressure sensitive vinyl tape of matching colour.
 - .8 Special requirements:
 - .1 Outdoor: UV rated material at least 0.5 mm thick.
 - .9 Covering adhesive: Compatible with insulation.
- .2 ABS Plastic:
 - .1 One-piece moulded type and sheet with pre-formed shapes as required.
 - .2 Colours: to match adjacent finish paint selected by Architect.
 - .3 Minimum service temperatures: -40°C.
 - .4 Maximum service temperature: 82°C.
 - .5 Moisture vapour transmission: 0.012 perm.
 - .6 Thickness: 0.75 mm.

- .7 Fastenings:
 - .1 Solvent weld adhesive compatible with insulation to seal laps and joints
 - .2 Tacks.
 - .3 Pressure sensitive vinyl tape of matching colour.
- .8 Locations:
 - .1 For outdoor use ONLY.

- .3 Aluminum:
 - .1 In accordance with ASTM B209.
 - .2 Thickness: 0.50 mm sheet.
 - .3 Finish: Smooth.
 - .4 Joining: Longitudinal and circumferential slip joints with 50 mm laps.
 - .5 Fittings: 0.5 mm thick die-shaped fitting covers with factory-attached protective liner.
 - .6 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5 mm thick at 300 mm spacing.

2.5 INSULATION SECUREMENTS

- .1 Tape: Self-adhesive, aluminum, reinforced, 50 mm wide minimum.
- .2 Contact adhesive: Quick setting.
- .3 Canvas adhesive: Washable.
- .4 Tie wire: 1.5 mm diameter stainless steel.
- .5 Bands: Stainless steel, 19 mm wide, 0.5 mm thick.
- .6 Facing: 25 mm galvanized steel hexagonal wire mesh on both faces of insulation.
- .7 Fasteners: 4 mm diameter pins with 35 mm square clips. Length of pin to suit thickness of insulation.

2.6 VAPOUR RETARDER LAP ADHESIVE

- .1 Water based, fire retardant type, compatible with insulation.

2.7 INDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.

2.8 OUTDOOR VAPOUR RETARDER MASTIC

- .1 Vinyl emulsion type acrylic, compatible with insulation.
- .2 Reinforcing fabric: Fibrous glass, untreated 305 g/m².

Part 3 Execution

3.1 PRE- INSTALLATION REQUIREMENTS

- .1 Pressure testing of equipment and adjacent piping systems complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

3.2 INSTALLATION

- .1 Install in accordance with TIAC National Standards:
 - .1 Hot equipment: To TIAC code 1503-H.
 - .2 Cold equipment: to TIAC code 1503-C.
- .2 Elastomeric insulation: to remain dry. Overlaps to manufacturer's instructions. Joints tight and sealed properly.
- .3 Provide vapour retarder as recommended by manufacturer.
- .4 Apply materials in accordance with insulation and equipment manufacturer's instructions and this specification.
- .5 Use two layers with staggered joints when required nominal wall thickness exceeds 75 mm.
- .6 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes:
 - .1 Hangers, supports outside vapour retarder jacket.
- .7 Supports, Hangers:
 - .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

3.3 REMOVABLE, PRE-FABRICATED INSULATION AND ENCLOSURES

- .1 Application: At expansion joints, valves, primary flow measuring elements, flanges, chilled water pumps, and unions at equipment.
- .2 Installation to permit movement of expansion joint and to permit periodic removal and replacement without damage to adjacent insulation.

3.4 EQUIPMENT INSULATION SCHEDULES

- .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.
- .2 Hot equipment:
 - .1 TIAC code A-1 with mechanical fastenings or wire and 13 mm cement reinforced with one layer of reinforcing mesh.
 - .2 Thicknesses:
 - .1 Expansion Tanks: 25 mm Type A-1, PVC jacket.

- .2 Combination air, dirt, hydraulic and magnetic separator: 25 mm Type A-1, PVC jacket.
- .3 Finishes:
 - .1 Equipment in mechanical rooms: TIAC code CEF/1 with aluminum jacket unless specified otherwise.

END OF SECTION