

**Part 1 General**

**1.1 GENERAL REQUIREMENTS**

- .1 The Contractor shall be responsible to carry out all the Work set out or referred to in this Section 23 31 13 01.

**1.2 SUMMARY**

- .1 Section Includes:
  - .1 Materials and installation of low-pressure metallic ductwork, joints and accessories.
  - .2 Sustainable requirements for construction and verification.
- .2 Related Sections:
  - .1 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

**1.3 REFERENCES**

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
- .2 American Society for Testing and Materials International, (ASTM):
  - .1 ASTM A480/A480M-03c, Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
  - .2 ASTM A635/A635M-02, Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot Rolled.
  - .3 ASTM A653/A653M-03, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
- .3 Health Canada/Workplace Hazardous Materials Information System (WHMIS):
  - .1 Material Safety Data Sheets (MSDS).
- .4 National Fire Protection Association (NFPA):
  - .1 NFPA 90A-02, Standard for the Installation of Air-Conditioning and Ventilating Systems.
  - .2 NFPA 90B-02, Standard for the Installation of Warm Air Heating and Air-Conditioning Systems.
- .5 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA):
  - .1 SMACNA HVAC Duct Construction Standards - Metal and Flexible, 2nd Edition 1995 and Addendum No. 1, 1997.
  - .2 SMACNA HVAC Air Duct Leakage Test Manual, 1985, 1st Edition.
  - .3 IAQ Guideline for Occupied Buildings Under Construction 1995, 1st Edition.

**1.4 SUBMITTALS**

- .1 Submit shop drawings and product data in accordance with Division 01 – General Requirements.

- .2 Product Data: submit WHMIS MSDS - Material Safety Data Sheets in accordance with Division 01 – General Requirements for the following:
  - .1 Sealants.
  - .2 Tape.
  - .3 Proprietary joints.
- .3 Co-ordinate submittal requirements and provide submittals required by Division 01 – General Requirements.
- .4 Submit Indoor Air Quality (IAQ) Management Plan in accordance with Division 01 – General Requirements.
- .5 Indicate VOC's for adhesives and solvents during application and curing.

## **1.5 QUALITY ASSURANCE**

- .1 Certification of Ratings:
  - .1 Catalogue or published ratings shall be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.
- .2 Health and Safety:
  - .1 Construction occupational health and safety in accordance with Division 01 – General Requirements.
- .3 Indoor Air Quality (IAQ) Management Plan:
  - .1 Develop and implement an Indoor Air Quality (IAQ) Management Plan in accordance with Division 01 – General Requirements.
  - .2 During construction meet or exceed the requirements of SMACNA IAQ Guideline for Occupied Buildings under Construction.
- .4 Sustainable Requirements:
  - .1 Construction requirements: in accordance with Division 01 – General Requirements.
  - .2 Verification: Contractor's verification in accordance with Division 01 – General Requirements.

## **1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Protect on site stored or installed absorptive material from moisture damage.
- .2 Store and manage hazardous materials in accordance with Division 01 – General Requirements.
- .3 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Division 01 – General Requirements.

- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Separate for reuse and recycling and place in designated containers steel, metal, plastic waste in accordance with Waste Management Plan.
- .5 Place materials defined as hazardous or toxic in designated containers.
- .6 Handle and dispose of hazardous materials in accordance with CEPA, TDGA and Applicable Laws.
- .7 Fold up metal and plastic banding, flatten and place in designated area for recycling.

## **Part 2 Products**

### **2.1 SUSTAINABLE REQUIREMENTS**

- .1 Materials and resources in accordance with Division 01 – General Requirements.

### **2.2 SEAL CLASSIFICATION**

- .1 Classification as follows:

| <b>Maximum Pressure Pa</b> | <b>SMACNA Seal Class</b>                         |
|----------------------------|--|
| 500                        | A – All HVAC supply and return duct unless noted |
| 250                        | B – All exhaust Ducts unless noted               |

- .2 Seal classification:
  - .1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.
  - .2 Class B: longitudinal seams, transverse joints and connections made airtight with sealant, tape or combination thereof.

### **2.3 SEALANT**

- .1 Sealant: oil resistant, polymer type flame resistant duct sealant. Temperature range of minus 30°C to plus 93°C.
- .2 Indicate VOC's during application and curing.

### **2.4 TAPE**

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.

### **2.5 DUCT LEAKAGE**

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.

### **2.6 FITTINGS**

- .1 Fabrication: in accordance with SMACNA.

- .2 Radiused elbows:
  - .1 Rectangular: standard radius Centreline radius: 1.5 times width of duct.
  - .2 Round: five piece. Centreline radius: 1.5 times diameter.
- .3 Mitred elbows, rectangular:
  - .1 To 400 mm (16"): with double thickness turning vanes.
  - .2 Over 400 mm (16"): with double thickness turning vanes.
- .4 Branches:
  - .1 Rectangular main and branch: with radius on branch 1.5 times width of duct 45° entry on branch.
  - .2 Round main and branch: enter main duct at 45° with concentric conical connection.
  - .3 Provide volume control damper in branch duct near connection to main duct unless otherwise noted.
  - .4 Main duct branches: with splitter damper.
- .5 Transitions:
  - .1 Diverging: 20 degrees maximum included angle.
  - .2 Converging: 30 degrees maximum included angle.
- .6 Offsets:
  - .1 Full radius elbows.
- .7 Obstruction deflectors: maintain full cross-sectional area:
  - .1 Maximum included angles: as for transitions.

## **2.7 FIRE STOPPING**

- .1 Retaining angles around duct, on both sides of fire separation in accordance with Section 07 84 00 - Firestopping.
- .2 Fire stopping material and installation must not distort duct.

## **2.8 GALVANIZED STEEL**

- .1 Lock forming quality: in accordance with ASTM A653/A653M, Z90 zinc coating.
- .2 Thickness, fabrication and reinforcement: in accordance with SMACNA.
- .3 Joints: in accordance with SMACNA proprietary manufactured duct joint.
- .4 Round Duct: Spiral wound locked seam; made for high static ventilation system.

## **2.9 HANGERS AND SUPPORTS**

- .1 Hangers and Supports: Refer to 23 05 29 – Hangers and Supports for HVAC Piping and Equipment for General Requirements:
  - .1 Strap hangers: of same material as duct but next sheet metal thickness heavier than duct.

- .1 Maximum size duct supported by strap hanger: 500mm round or single side.
- .2 Hanger configuration: in accordance with ASHRAE and SMACNA.
- .3 Hangers: galvanized steel angle with galvanized steel rods shall be in accordance with the following table:

| <b>Duct Size (mm)</b> | <b>Angle Size (mm)</b> | <b>Rod Size (mm)</b> |
|-----------------------|------------------------|----------------------|
| up to 750             | 25 x 25 x 3            | 6                    |
| 751 to 1050           | 40 x 40 x 3            | 6                    |
| 1051 to 1500          | 40 x 40 x 3            | 10                   |
| 1501 to 2100          | 50 x 50 x 3            | 10                   |
| 2101 to 2400          | 50 x 50 x 5            | 10                   |
| 2401 and over         | 50 x 50 x 6            | 10                   |

- .4 Upper hanger attachments:
  - .1 For concrete: manufactured concrete inserts.
  - .2 For steel joist: manufactured joist clamp.
  - .3 For steel beams: manufactured beam clamps.

## **2.10 FLEXIBLE DUCTWORK**

- .1 Underwriters Laboratories UL 181 and CUL S110 listed, and complies with NFPA Standards 90A and 90B.
- .2 Flame spread rating not to exceed 25. Smoke developed rating not to exceed 50.
- .3 Duct shall be factory made and composed of a resilient calendared film liner duct permanently bonded to a coated spring steel wire helix and supporting a fiberglass insulating blanket. Low permeability outer vapor barrier of fiberglass reinforced film laminate shall complete the composite.

## **Part 3 Execution**

### **3.1 GENERAL**

- .1 Do work in accordance with NFPA 90A, NFPA 90B, ASHRAE, SMACNA and as indicated.
- .2 Do not break continuity of insulation vapour barrier with hangers or rods:
  - .1 Insulate strap hangers 100 mm beyond insulated duct. Ensure diffuser is fully seated.
- .3 Support risers in accordance with ASHRAE, SMACNA.
- .4 Install breakaway joints in ductwork on sides of fire separation.
- .5 Install proprietary manufactured flanged duct joints in accordance with manufacturer's instructions.

- .6 Manufacture duct in lengths and diameter to accommodate installation of acoustic duct lining.

### 3.2 HANGERS

- .1 Strap hangers: install in accordance with SMACNA.
- .2 Angle hangers: complete with locking nuts and washers.
- .3 Hanger spacing: in accordance with ASHRAE, SMACNA as follows:

| Duct Size (mm) | Spacing (mm) |
|----------------|--------------|
| to 1500        | 3000         |
| 1501 and over  | 2500         |

### 3.3 SEALING AND TAPING

- .1 Apply sealant to outside of joint in accordance with manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturers recommendations.

### 3.4 LEAKAGE TESTS

- .1 Refer to Section 23 05 94 - Pressure Testing of Ducted Air Systems.
- .2 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .3 Do leakage tests in sections.
- .4 Make trial leakage tests as instructed to demonstrate workmanship.
- .5 Do not install additional ductwork until trial test has been passed.
- .6 Test section minimum of 30 m (98 feet) long with not less than three branch takeoffs and two 90 degree elbows.
- .7 Complete test before performance insulation or concealment Work.

### 3.5 FIELD QUALITY CONTROL

- .1 Verification requirements in accordance with Division 01 – General Requirements, include:
  - .1 Materials and resources.
  - .2 Storage and collection of recyclables.
  - .3 Construction waste management.
  - .4 Resource reuse.
  - .5 Recycled content.
  - .6 Local/regional materials.
  - .7 Low-emitting materials.

END OF SECTION