

Part 1 General

1.1 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 01 – Common Work Results – Electrical.

Part 2 Products

2.2 JUNCTION AND PULL BOXES

- .1 Welded steel construction with screw-on flat covers for surface mounting.
- .2 Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 JUNCTION AND PULL BOXES INSTALLATION

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Install pull boxes so as not to exceed 30 m of conduit run or 2-90° bends between pull boxes.

3.3 IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results – Electrical.
- .2 Install size 2 identification labels for splitters indicating equipment served, voltage, phase and amperage.

END OF SECTION