

Part 1 General

1.1 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 01 – Common Work Results – Electrical.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA) Latest Edition of the following:
 - .1 CAN/CSA C22.2 No. 18.3-04 Conduit, Tubing and Cable Fittings.
 - .2 CSA C22.2 No. 56-04 Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
 - .3 CSA C22.2 No. 83-M 1985 (R2003), Electrical Metallic Tubing.
 - .4 CSA C22.2 No. 211.2-M 1984 (R2003), Rigid PVC (Unplasticized) Conduit.

Part 2 Products

2.1 CONDUITS

- .1 Electrical metallic tubing (EMT): to CSA C22.2 No. 83 – M 1985 (R2003), with couplings.
- .2 Flexible metal conduit: to CSA C22.2 No. 56-04, steel and liquid-tight flexible metal.

2.2 CONDUIT FASTENINGS

- .1 One-hole steel straps to secure surface conduits 51 mm and smaller. Two hole steel straps for conduits larger than 51 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits at 1.5 m oc.
- .4 Threaded rods, 6 mm diameter, to support suspended channels.

2.3 CONDUIT FITTINGS

- .1 Rain tight EMT connectors shall be used on "vertical" sections of conduit runs where terminating into tops of electrical equipment incorporating drip shields or hoods.
- .2 Fittings: Use set screw connectors and fittings for EMT. Coating: same as conduit.
- .3 Factory "ells" where 90 degree bends are required for 25 mm and larger conduits.
- .4 Connectors for flexible conduits, shall be set screw galvanized steel.
- .5 Connectors for liquid tight flexible conduit shall be water tight, compression type galvanized steel.

- .6 Threaded plastic or metal bushings to be installed on all EMT connector's sizes 35 mm and larger.
- .7 Fittings: manufactured for use with conduit specified. Coating: same as conduit.

2.4 FISH CORD

- .1 Polypropylene – tensile strength as required.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms and in unfinished areas.
- .3 EMT shall be installed as a complete system.
- .4 Support of electrical systems raceway shall be independent of any type of suspended ceiling support rods, wires, etc. and mechanical piping or duct systems.
- .5 Use electrical metal tubing (EMT) for all work, unless otherwise indicated. Provide a separate green ground for all conduit systems, including E.M.T.
- .6 Flexible Metal Conduit:
 - .1 Flexible metal conduits, permitted above T-bar ceilings, for drops to various fire alarm devices mounted on flush outlet boxes in finished ceiling. Minimum size of flexible conduit: 22 mm, Maximum length of drop: 1.5 m.
- .7 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment, furniture and transformers. Include a separate ground wire.
- .8 Minimum conduit size for lighting and power circuits: 16 mm.
- .9 Bend conduit cold. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .10 Mechanically bend steel conduit over 22 mm dia.
- .11 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .12 Install fish cord in empty conduits.

- .13 Remove and replace blocked conduit sections. Do not use liquids to clean out conduits.
- .14 Dry conduits out before installing wire.
- .15 Securely fasten in place within 83 mm of each outlet box, junction box, cabinet, coupling or fitting, maximum spacing between supports as follows:
 - .1 1.5 m for 21 mm trade size conduit and smaller.
 - .2 2 m for 27 mm to 35 mm trade size conduit.
 - .3 3 m for 41 mm trade size and larger.
- .16 Ground Wires:
 - .1 Provide a separate green ground wire in all conduits, including EMT.

3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Run conduits in flanged portion of structural steel.
- .3 Group conduits wherever possible on suspended or surface channels.
- .4 Do not pass conduits through structural members except as indicated.
- .5 Do not locate conduits less than 76 mm parallel to steam or hot water lines with minimum of 25 mm clearance at crossovers.

3.4 CONCEALED CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

END OF SECTION