

Part 1 General

1.1 SECTION INCLUDES

- .1 Materials and installation for contactors for system voltages up to 600V.

1.2 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 01 – Common Work Results – Electrical.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.2 No.14-95 (R2005), Industrial Control Equipment.

1.4 SUBMITTALS

- .1 Submit Shop Drawings in accordance with Section 26 05 01 – Common Work Results – Electrical.

Part 2 Products

2.1 CONTACTORS

- .1 Contactors: to CSA C22.2 No.14.
- .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
- .3 Number of poles as indicated.
- .4 Complete with 2 normally open and 2 normally closed auxiliary contacts unless indicated otherwise.
- .5 Mount in CSA Type 1 Enclosure unless otherwise indicated.
- .6 Include following options in cover:
 - .1 Red indicating lamp.
 - .2 Hand-Off-Auto selector switch.
- .7 Control transformer: Confirm coil voltage prior to ordering.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.
- .2 Size 4 nameplate indicating name of load controlled as indicated.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install contactors and connect auxiliary control devices.

END OF SECTION