



**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Email:

pc.soumissionsest-bidseast.pc@canada.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 25 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO A
INVITATION TO TENDER**

**RÉVISION 001 INVITATION À
SOUMISSIONNER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :

Parks Canada Agency
National Contracting Services
Québec (Québec)

Title - Sujet : New Service Building E, Kouchibouguac National Park, NB.	
Solicitation No. - N° de l'invitation : 5P201-20-0024/A	Date : July 24, 2020
Amendment No. - N° de modification : 001	
Client Reference No. - N° de référence du client : 954	
GETS Reference No. N° de référence de SEAG : PW-20-00919752	

Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : August 4, 2020	Time Zone - Fuseau horaire EDT – HAE
---	--

F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Sébastien Thiboutot		
Telephone No. - N° de téléphone : 418-575-2052	Fax No. -N° de télécopieur : N/A	Email Address – Courriel : sebastien.thiboutot@canada.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein		

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de téléphone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P201-20-0024/A

Amd. No. - N° de la modif. :
001

Contracting Authority - Autorité contractante :
Sébastien Thiboutot

Client Ref. No. - N° de réf. du client :
954

Title – Titre :
New Service Building E, Kouchibouguac National Park, NB.

Revision 001

This amendment is raised to:

- A. Answer questions from Bidders.

A. Questions and Answers

Q1. On E-102 detail #1 and note #1 they have 2C #4 teck 90. I believe it should be 3C #4 teck 90 as it is 120/240 volt 1 phase.

A1. Ref. Drawing No. E-102 – Electrical Single Line Diagram and Site Plan
Ref. Detail 1/E-102 – Single Line Diagram.

Delete "2C #4 Teck 90, See Note 1."
Replace with "3C #4 Teck 90, See Note 1."

Ref. Note 1.

Delete "2C #4 AWG Teck 90"
Replace with "3C #4 Teck 90."

Q2. I read through specs, is this all wood construction? Can we run lumex wiring or does it have to be AC90 bx?

A2. Building E is wood construction.
Ref. Para 26 05 21 Page 2, Para 2.3.2 Type: AC90.
Lumex wiring is not permitted.

Q3. We'd like to get the following "Anotec"™ products approved for this job if possible: Series 3400 Curtainwall, Series 21 Doors (narrow stile thermally broken), & Series 80 Windows (3" depth)?

A3. Material selections and finishes on this building are intended to match all other adjacent Service Buildings in use at this national park. This includes all interior washroom accessories, electrical and plumbing fixtures, and ceramic tile and millwork finishes. At the exterior of the new building, the asphalt shingled roof, new vertical stained cedar siding, red cedar accent wall, and new aluminium windows and doors will all match existing conditions. Refer to specifications for details. No product substitutions from the ones specified in the documents will be accepted. Use the Basis-of-Design and Acceptable Materials Listings to establish a bid price unless an Addendum is issued adding additional Acceptable Materials.

Where substitute products are permitted, the Contractor will assemble requests for substitutions requested by subcontractors and submit to Departmental Representative for review. Departmental Representative will review proposed substitute products for acceptability only when the required information is submitted by the Contractor.

For further details refer to the Tender Notice Documents including but not limited to Specifications Section 01 11 10 GENERAL REQUIREMENTS and 1.15 PRODUCT OPTIONS AND SUBSTITUTIONS: Points and following points under: .15.1 Definitions, .15.2 Submittals, .15.3 Product Options and .15.4 Substitutions.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED