



**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Email:

pc.soumissionsest-bidseast.pc@canada.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 25 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 002 TO A
INVITATION TO TENDER**

**RÉVISION 002 INVITATION À
SOUMISSIONNER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :

Parks Canada Agency
National Contracting Services
Québec (Québec)

Title - Sujet : Church and monuments repointing –Grand Pré National Historic Site, NS.	
Solicitation No. - N° de l'invitation : 5P201-20-0025/A	Date : July 29, 2020
Amendment No. - N° de modification : 002	
Client Reference No. - N° de référence du client : 1241	
GETS Reference No. N° de référence de SEAG : PW-20-00919859	

Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : August 6, 2020	Time Zone - Fuseau horaire EDT – HAE
---	--

F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Sébastien Thiboutot		
Telephone No. - N° de téléphone : 418-575-2052	Fax No. -N° de télécopieur : N/A	Email Address – Courriel : sebastien.thiboutot@canada.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein		

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de téléphone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P201-20-0025/A

Amd. No. - N° de la modif. :
002

Contracting Authority - Autorité contractante :
Sébastien Thiboutot

Client Ref. No. - N° de réf. du client :
1241

Title – Titre :
Church and Monuments Repointing – Grand Pré National Historic Site, NS.

Amendment 002

This amendment is raised to:

- A. Answer bidder's questions.

A. Questions and Answers

- Q1. The specification indicates both 1:2:6 and 1:2:9 mortar mixes with the acceptable manufactures being Daubois and King to be used for this project. It also indicates that for the work up to 1m above the ground level there is to be the addition of latex added to the mortar. In our experience Latex would not be added to a historical repoint project and would also cause a large variation in the mortars properties. In addition the 3 variations of mortar will not have the same colour tone when cured and will have a visually different appearance. Is this how we are to proceed with pricing this project or will we be using a unified historical mortar throughout the repointing work to have a uniform appearance, also there will be no warranty from Daubois if Latex is added to their product.**
- A1.** We will be using one historical mortar throughout the repointing work for a unified appearance. The mortar formula should be simple and preferably without additives. The colours should be achieved with the sand colours from the local sources that possibly was used for the original mortar mix. We will use mock ups to determine the best colour and mix.
- Q2. The specification section 01 11 00 1.9.2 and 01 45 00 1.3.1 indicates that all cost of testing will be borne by the PCA representative, however in section 04 03 05 1.6.10 (period masonry Repointing) it indicates that the testing cost will be borne by the contractor.**
- A2.** Costs for testing will be by the contractor.
- Q3. Will we have to maintain public access through the front entry during the project.**
- A3.** The public will not be visiting the church.
- Q4. It is indicated in section 01 11 00 1.4.2 that the hours of noise and vibration causing work will only be conducted between 10:00 to 15:00 hours Monday to Friday. Please note that this will act to increase the schedule over a typical 8 to 10 hour work day and push the schedule further into a period of inclement weather that will create more costs for maintaining the site and accommodating the weather conditions, are these hours of work to be enforced?**
- A4.** The work day can be 8:00AM - 8:00PM

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED