



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Box/Boîte de Réception des
Soumissions
1st Floor/1^{ère} étage, Suite 1212
100-1045 Main Street
Moncton
New Brunswick
E1C 1H1
Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Acquisitions NB/PEI (Moncton Office) – Bureau
d'acquisitions N.-B./Î.-P.-É. (Moncton)
1045 Main Street / 1045, rue Main
Moncton
New Bruns
E1C 1H1

Title - Sujet Condensing Boilers- Fredericton, NB	
Solicitation No. - N° de l'invitation EC373-210497/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EC373-210497	Date 2020-08-04
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-005-5744	
File No. - N° de dossier PWJ-0-43017 (005)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-08-06	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lomax (PWJ), Sandra	Buyer Id - Id de l'acheteur pwj005
Telephone No. - N° de téléphone (506) 639-8503 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro 2 est soumise et comprend la modification numéro 2 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas

Modification numéro 2

Question et Réponse

Question 1 – Compressed Air Line: Upon site inspection it was noticed that there is a compressed air line which will be interfering with the installation of new pipework. Please confirm if we are to move the compressed air line that it will be the responsibility of the contractor to relocate the line for installation of new pipework.

Réponse 1 - Project scope is to include re-routing of CA lines as required to permit heating piping installation.

Question 2 - Heating Lines: There are multiple additional connection points from the main line which is to be replaced that are not shown on the plans. Please confirm we are to re-connect these lines to the new heating water lines which are being replaced.

Réponse 2 - Project scope is to include re-connection of any affected heating lines.

Question 3 - Gas Piping: The drawings show a connection to the main gas line (3" diameter). Since this connection is connecting to a 3" gas line, we will need to weld the new branch line to the existing main gas line. We will need to shut down the system in order to complete the welding. There is a 3" line going to the boilers, which has a valve connected close to the main line. Is it possible to connect the new branch line downstream of the valve in order to prevent a full shutdown of the gas in the building in order to minimize downtime?

Réponse 3 - The tie-in location is to be done as shown on plans. Tie-in to be completed prior to the heating season, include isolation valve as required.